



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND RESCUE SERVICES UT LADAKH

(e-mail-soto-igp@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - F&RS/Dir/NOC /2024-19641-42

Dated: - 20 /11/2024

Subject: Fire NOC of Kendriya Vidyalaya School, Leh.

The report has been submitted by Superintendent of Police, F&ES, Ladakh regarding the inspection of the instant school building wherein the spot visit has been conducted by I/C Fire and Rescue Services Station, Leh. The detailed report of the school building is as under:

Location/ Accessibility:

The School is constructed at choglamsar, Leh. It is located at latitude 34.129531 and longitude 77.588561. The site is approximately 05 Kms away from Fire and Rescue Services Station, Leh. It takes approximately 09 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The school building is two storied. In the ground floor there are Principal office, Main office, ATAL Lab, NIOS room, Medical room, sports room, Music room, office store, 02 store room, class 1, class 2, class 3, class 4, class 6, class 7, class 9A, Class 10 B, class 11A, class 11B, Class 12C, Library and Chemistry Lab. Principal Office has 02 window and the size is 2x4 ft. Main office has 02 window and the size is 2x4. ATAL lab and NIOS room has 02 window in each room and the size is 3x4 ft. Medical room, Sports room, Music room, store room and all class room has 02 window having size 5x10 ft. Chemistry lab has two exit and 09 window having size 3x4 ft. 1st floor has Language lab, Computer lab, Examination department, store room, art room, astronomy lab, Primary exam department, CMP Room, Class 5, Class 8A, Class 8B, Class 11 C, Junior Science lab, staffroom, Class 12A, Class 12B, Bio lab and Physics Lab.

The following Fire Safety equipment's which are installed in School Building:

1. 11 number of fire extinguisher ABC Type 4 kg capacity is installed in the school building.
2. 01 number of CO₂ type fire extinguisher 4.5 kg capacity is installed in the computer lab.
3. 10 number of sand bucket is installed in the school premises.
4. 05 number of plastic water tank 500 liters capacity overhead of the building.
5. 20 thousand liters underground reserve water tank shall is made in the school premises.

FIRE NOC is given in the favour of Kendriya Vidyalaya School, Leh for period of One year from the issuance.

Director,
Fire and Rescue Services,
UT Ladakh.

Copy to:

01. Principal, Kendriya Vidyalaya School, Leh for information.
02. Superintendent of Police, F&RS, Ladakh for information.
03. Office file.