



भारत सरकार
Government of India
केंद्रीय लोक निर्माण विभाग
Central Public Works Department



कार्यपालक अभियंता का कार्यालय- कन्नूर
अभिलाश पर्यटक गृह भवन
रेलवे स्टेशन रोड,
कन्नूर, केरल - 670 001

Office of the Executive Engineer -Kannur
CPWD, 2nd Floor Bldg No.CB-40/1143
Abhilash Tourist Home Building
Railway Station Road, Kannur, Kerala-670 001

PH: 0497-2967449	FAX: 0497-2707449	E mail:eekannur@gmail.com	Web:www.cpwd.nic.in
सं: 23(151)/क. के.म./2025/ 931(11)			दिनांक: 16/09/2025

✓ सेवा में:

The Principal,
Kendriya Vidyalaya,
Keltron Nagar,
Kannur-670 561

विषय: Inspection of Old School Building - reg.

संदर्भ : Letter No.31098/98/KVKN/2026-5-26 Dated:15.09.2025

महोदय,

The old school building was inspected along with the Principal and The Assistant Engineer CPWD Kannur on 16/09/2025.

The building is an old load bearing structure, constructed with laterite masonry and Mangalore tile roofing on wooden rafters and reapers. Due to the old age the tiles are fallen and broken and the wooden reapers are termite affected. The height of the building and width of the verandah is lesser when compared with the required standards. Considering the old age and deterioration, it is felt that the building is beyond economical repair and hence recommended for demolition.

भवदीय

(पी. के. जोस)

कार्यपालक अभियंता
के. लो. नि. वि., कन्नूर

प्रतिलिपि प्रेषित: Assistant Engineer, KaCSD III, CPWD, Kannur for information

कार्यपालक अभियंता - कन्नूर