

Tele: - 8900479900/ 03222-232741

Air Fore Stn Kalaikunda
City- Kharagpur,
Distt- Medinipur West
West Bengal-721303

5W/2654/2/Fire

25 Jun 24

Principal
Kendriya Vidyalaya No. 1
AFS Kalaikunda

FORWARDING OF FIRE EXTINGUISHERS
SERVICEABILITY CHECK CERTIFICATE

Respected Ma'am,

1. Reference is made to your letter F.25201/KV1/KKD/2024-25/Admin dated 19 Jun 24.
2. Annexed herewith please find the serviceability check certificate for fire extinguishers held with your school. It is also suggested that unserviceable extinguishers may please be replaced on priority to prevent untoward fire incident.
3. Submitted, please.

Yours sincerely,



(MK Janmeda)

JWO


Stn Fire Offr


Annexure: - As stated

CERTIFICATE


Certified that Fire Extinguishers placed at different locations of KVS-I, AFS Kalaikunda were inspected on 24 Jun 24. Details are as follows: -

SI No.	Type of extinguishers	Qty	'S'	'U/S'
1.	01 Kg ABC/DCP Fire Extinguisher	05	05	Nil
2.	02 Kg ABC/DCP Fire Extinguisher	05	03	02
3.	04 Kg ABC/DCP Fire Extinguisher	30	25	05
4.	4.5 Kg ABC/DCP Fire Extinguisher	02	02	Nil
5.	05 Kg ABC/DCP Fire Extinguisher	02	01	01
6.	06 Kg ABC/DCP Fire Extinguisher	04	04	Nil


(Madan Kumar)
Cpl


(एम के जनमेदा / MK Janmeda)
जू.वा.अ. / JWO
स्टे फायर अफसर / Stn Fire Offr
5 विंग, वायु सेना / 5 Wg, AF
24 Jun 24

COUNTERSIGNED


(सुखबीर कौर मिनहास / SK Minhas)
ग्रुप कैप्टन / Gp Capt
मुख्य प्रशासनिक अधिकारी / C Adm O
5 विंग, वायु सेना / 5 Wing, AF

24 JUN 2024