

# JHARGRAM MAHAKUMA JANASIKSHA PRASAR SAMITY S.D.L

## JHARGRAM PHED

Sponsored By: Govt. of West Bengal

Monitored By: Jhargram Mahakuma Janasiksha Prasara Samity

Raghunathpur :: Jhargram :: (03221) 255329

Source Type:- W/T.W./D.T./Other (Specify)..... Submersible Pump.

Collected By:

Tapan Kumar Patra.

Collected From:

PM Shri Kendiya Vidyalaya No-1

AFS Kalaikunda,

Dist - Paschim Medinipur.

Collected on:- 22.08.24

Test Completed on:- 27.08.24

Physical Appearance:-

Clear / Turbid (Turbidity..... 1.93)

Smell:- No Smell.

### Microbial Test Findings:-

Sl. No.	Test Performed	Unit	Result	Normal Range
1	Total Coliform	MPN/100ml	NIL	00
2	Faecal Coliform	MPN/100ml	NIL	00

### Chemical Test Findings:

Sl.No.	Test Performed	Unit	Result	AL-PL
1	pH	mg/Ltr	6.49	6.5-8.5
2	Residual Chlorine	mg/Ltr	NIL	0.2-2.00
3	Total Iron As Fe	mg/Ltr	0.22	1.0
4	Manganese	mg/Ltr	0.10	0.1-0.3
5	Total Hardness	mg/Ltr	38	200-600
6	TDS	mg/Ltr	70.6	500

### Remarks:

The Sample Water is Chemically Safe / ~~Unsafe~~:

The Sample Water is Bacteriologically Safe / ~~Unsafe~~:-

Suggestion : 1) .....

2) .....

Secretary  
Jhargram Mahakuma  
Janasiksha Prasara Samity

Chemist  
Water Testing Laboratory  
Jhargram

Bacteriologist  
Water Testing Laboratory  
Jhargram

# ERAL WATER TESTING LABORATORY JHARGRAM

(PHED, Govt. of W.B. Approved)

JHARGRAM MAHAKUMA JANASIKSHA PRASAR SAMITY

VILL - RAGHUNATHPUR :: P.O.- JHARGRAM :: DT.- PASCHIM MEDINIPUR

Phone : 255-329 / 256-682 (03221)


513

Date 27.08.2024

i thanks a sum of Rupees ..... Three hundred only,

pm Shri Kendiya Vidyalaya.

one water sample testing.



Chemist

Water Testing Laboratory  
Jhargram

Secretary

300/-


2168/KV Corrs/ 121 /E2

06 Jul 2024

✓ PM Shri KV No-1  
AFS Kalaikunda

**BUILDING SAFETY CERTIFICATE AND PORTABLE WATER SAFETY**  
**CERTIFICATE FOR OU R VIDYALAYA**

1. Ref your letter No F 25201/KV1/KKD/2024-25/ADMN/61 dt 24 Jun 2024.
2. The structured stability of the building can be ascertained only after testing i.e by Non Destructive Test (NDT) of various members of the structure for which as amount **Rs 1.5 Lakhs** is required to be sanctioned.
3. However, pending sanction of the above said work, the structure is safe from visual inspection point of view, as no major damage is visible.
4. Apart from Ser No 3, the following points has been observed during inspection and needs to be ascertain by projecting of special repair work subject to release of funds for further repair :-
  - (a) Seepage from the roof found at various location of several No of buildings.
  - (b) Flooring found broken & damaged at No of places in passage, class rooms etc.
  - (c) Plaster found deteriorated/rusted from walls at various places.
  - (d) Seepage/leakage found in children toilet.
  - (e) Painting found very old & colour faded.
  - (f) Door window found broken in various classroom including several other nature of defects.
5. It is certified that water used in your school is safe for usage and it is tested on regular intervals through PHE department /SMC of this AF Stn.
6. This is for your info and necessary action n please.

  
(Gautam Kumar)  
AE (Civil)  
AGE 'T'  
for Garrison Engineer (AF) KKD

**Copy to :-**

AGE (B&R)-I Kalaikunda }  
AGE (E&M) Kalaikunda } for info please.