Tele /Fax: 03222-232138/232010
E mail ID: afkalai4-mes@nic.in

Garrison Engineer (AF) Kalaikunda
Military Engineer Services
Post-Kalaikunda Air Field
Dist-Paschim Medinipur
PIN-721303

2168/KV Corrs/ 121 /E2

06 Jul 2024

PM Shri KV No-1
AFS Kalaikunda

BUILDING SAFETY CERTIFICATE AND PORTABLE WATER SAFETY CERTIFICATE FOR OU R VIDYALAYA

1. Ref your letter No F 25201/KV1/KKD/2024-25/ADMN/61 dt 24 Jun 2024.

2. The structured stability of the building can be ascertained only after testing i.e by Non Destructive Test (NDT) of various members of the structure for which as amount **Rs 1.5 Lakhs** is required to be sanctioned.

3. However, pending sanction of the above said work, the structure is safe from visual inspection point of view, as no major damage is visible.

4. Apart from Ser No 3, the following points has been observed during inspection and needs to be ascertain by projecting of special repair work subject to release of funds for further repair :-

(a) Seepage from the roof found at various location of several No of buildings.

(b) Flooring found broken & damaged at No of places in passage, class rooms etc.

(c) Plaster found deteriorated/rusted from walls at various places.

(d) Seepage/leakage found in children toilet.

(e) Painting found very old & colour faded.

(f) Door window found broken in various classroom including several other nature of defects.

5. It is certified that water used in your school is safe for usage and it is tested on regular intervals through PHE department /SMC of this AF Stn.

6. This is for your info and necessary action n please.

(Gautam Kumar)
AE (Civil)
AGE 'T'
for Garrison Engineer (AF) KKD

Copy to :-

AGE (B&R)-I Kalaikunda
AGE (E&M) Kalaikunda } for info please.

Scanned with OKEN Scanner