GOVERNMENT OF RAJASTHAN
राजस्थान सरकार

GA 55
GFAR 27 & 81

RECEIPT रसीद

Book No.
पुस्तक संख्या 015631

Receipt No.
रसीद संख्या 0080

Dated दिनांक 19/09/2025

Receipt from Principal PM Shri Kendriya Vidyalaya (BCR) Khajuwala BKN.
with letter No. 1259 dated 19/09/25
the sum of Rupees तीन सौ रुपये मात्र -
in cash / by cheque on account of एक जल नमूने का रसायनिक परीक्षण
in payment of चालान सं. CRN no. 0110863719 दिनांक 19/09/2025 द्वारा प्राप्त किया।
श्री _____ से
पत्र संख्या _____ दिनांक _____ के साथ
रुपये _____ नगद या चैक द्वारा _____

के निमित्त प्राप्त हुए।

₹ 300/-
अक्षरे तीन सौ रुपये मात्र -

Signature हस्ताक्षर
रोकड़पाल
जन स्वा. अभि. विभाग
Designation पद
क्षेत्रीय प्रयोगशाला बीकानेर

Scanned with CamScanner

Office of the Superintending Chemist
Public Health Engineering Department, Rajasthan
Regional Laboratory, Bikaner

Report of the Chemical Examination of Water

To
PRINCIPAL ,
PM SHRI KENDRIYA VIDYALAYA,
BSF KHAJUWALA BIKANER.

Reference No : 1259, Dated : 19/09/2025
Date of Receipt : 19/09/2025

District : BIKANER
Sample Taker : Kaushal Kishor

Source / Location	Permissible Value as per B.I.S : 10500/2012		Tank
			Storage Tank PM SHRI KENDRIYA VIDYALAYA KHAJUWALA
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source	
Village/Town			Beriyawali (CT)
Gram Panchayat			
Date of Collection			19/09/2025
Date of Examination			24/09/2025
Sample No.			1169

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.62
Turbidity(NTU)	1	5	1.4
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell less
Temperature	----	----	25
Total Alkalinity	200	600	100
Total Hardness (as CaCO3)	200	600	140
Calcium (as Ca)	75	200	24
Magnesium (as Mg)	30	100	19.52
Chloride(as Cl)	250	1000	40
Sulphate(as SO4)	200	400	20
Nitrate as(NO3)	45	45	7
Fluoride	1.0	1.5	0.21
Total Dissolved Solids	500	2000	269
Iron	1.0	No Relaxation	0
Residual Chlorine	0.2	1.0	0

NOT VALID FOR WATER QUALITY LEGAL CASES.

This Sample Not Collected by this Lab.

Remarks : Water is Potable (P)/Unpotable (U)
No.Lab./Tech.(chem)/2025-26/1169

Superintending Chemist
PHED Laboratory, Bikaner

Copy To :
1. Chief Chemist, State Laboratory Gandhi Nagar, Jaipur

Superintending Chemist
PHED Laboratory, Bikaner

Scanned with CamScanner