

GLOBAL FIRE & SAFETY SERVICES LLP

(Engineers / Consultants / Executors)

All Engineering Service beyond your Requirement & Expectations

Approved & Licensed by Directorate of Maharashtra Fire Services. (License No. MFS-LA/F-0602 A.D-0516 A.P-0072)

To.

Ref: GFSS/KV /Form B/G067

The Officer Incharge, Mumbai Fire Brigade, Vikroli Fire Station BMC Colony, LBS Road Vikroli (W), Mumbai-400079

FORM - B

[See Section 3(3) and Rule 4(2)]

Six monthly certificates to be given in every Jan and July by the owner or the occupier for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I / We have carried out Inspection of the Fire Prevention and Life Safety Measures installed in the Following building or **Premises namely**:

PM Shri Kendriya Vidyalaya, Bhandup L B S Marg, Gandhi Junction, Kanjurmarg, Mumbai-400026.

Description of Building / Premises: School

Low Rise Bldg. -A: Ground + 1 upper floors. 40 Class Rooms, 6 Labs, 5 Office Rooms Bldg. - B: 8 Class Rooms

I / We further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient conditions for the period July 2024 to **December 2024**, as required under provisions of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006(Mah.III of 2007). The details of the inspection of installation carried out by me / us are mentioned in the report appended herewith.

Place: Mumbai

Signature and Address of the Licensed Agency



Date: - 04.10.2024

M/s. GLOBAL FIRE & SAFETY SERVICES LLP.

LAXMAN JANARDAN INDORÉ Date: 2024.10.04 22:05:45

Digitally signed by LAXMAN JANARDAN INDORE

+05'30'

101, Asawari Aptt. L B S Marg, Chirag Nagar, Ghatkopar - (W), Mumbai - 40086. License No. MFS-LA/RF-450



GLOBAL FIRE & SAFETY SERVICES LLP

(Engineers /Consultants / Executors)
All Engineering Service beyond your Requirement & Expectations

Approved & Licensed by Directorate of Maharashtra Fire Services. (License No. MFS-LA/F-0602 & D-0516 & P-0072)

Detailed list of Installed Fire Fighting Equipment.

Name of Premises: PM Shri Kendriya Vidyalaya, Bhandup

L B S Marg, Gandhi Junction, Kanjurmarg, Mumbai- 400026.

Sr. No.	<u>Description</u>	Quantity	<u>Test</u> Remark	
1	Fire Bucket with Sand ,	4 buckets each	5 Sets.	ОК
2	Fire Extinguisher with ISI Mark:13385	C02 -3.0 kg	3 Nos.	OK
3	Fire Extinguisher with ISI Mark: 13385	CO2 – 2.0 kg	2 No.	OK
4	Fire Extinguisher with ISI Mark:15683	ABC – 2 kg	8 Nos.	OK
5	Fire Extinguisher with ISI Mark:15683	ABC – 5 kg	9 Nos.	ok
6	Fire Extinguisher Mechanical Foam,	9 lit	1 No.	ОК

Remark. (We further certify that the above system found satisfactorily in working condition After testing on 04/10/2024 by us.

Occupied as

: Vidyalaya

TYPE OF SYSTEM : Fire Extinguishers only

DOW

:04/10/2024

DOI

:04/10/2024

Inspected By : LAXMAN INDORE

CERTIFICATE DATE: 04/10/2024

FOR GLOBAL FIRE & SAFETY SERVICES LLP.

(Laxman Indore)

B E (Mech.), M I E (India),

Chartered Engineer,

Proficiency as Boiler Engr.

Cell No. 09833486968

e-mail :liindore@rediffmail.com

Trainer: First Aid, CPR, Fire Fighting, Safety.



Govt. of Maharashtra

Directorate of Maharashtra Fire Service Vidyanagri, Hans Bhugra Marg, Santacruz (East), Mumbai - 400 098, Tel-022-26677555, Fax-022-26677666 www.mahafireservice.gov.in

FORM N [(See section 9 (3) and rule 14] License to act as a License Agency for the purpose of Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-450 / RD- 422 / RP-90

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to M/s. Global Fire & Safety Services LLP., having their registered office at 101, Asavari CHS and their contact details are Office Number: 9833486968 and Email ID: globalfiresafetyllp@gmail.com with PAN registration No. AAQFG7036C and GST No. 27AAQFG7036C1ZC to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class C 2. Detection and Fire Suppression System: Class C 3. Passive System: Class C

M/s. Global Fire & Safety Services LLP., shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from 07.09.2023 to 06.09.2025 1012024.

Hatya Digitally signed by Hatyal Kiran Date: 2023.09.11 ASSIE PETO 1338 +05'30'

PERIOD: JUN 202. 4. toDER 202. 4. Santosh OU: JAN 20 Shilk endrighridhar REPRODUC LAXMAN Digital Of

Santosh Shridhar Date: 2023.09.11

Date: 07.09.2023

(SS Warick) Director JANARDA JANARDAN INDORE N INDORE 11:31:30 +05'30'

Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.



Shree Shivkrupa Enterprises

FIRE PROTECTION & SAFETY SYSTEMS

Suppliers of Fire Fighting Equipments, Hydrant System & Maintenance

Regd. Office : Shop No. 03, Kalpavarukah CHS, Plot No. 92/93, Sec - 23, Julnagar, Navi Mumbai - 400 705. Branch Office : 197/IA-18, Near Ram Mandir, Chakrapani Road, Bhosari, Pune - 411039. (Bhagvan Gavhane)

Mob: 9324392866 / 9970765431 / 9892330415 Tol: 022 00609415 Email: Shivkrops.97@reddfroait.com/shivarcfire@gmail.com

Ref. No: S.S.E/TC/033

Date: 16/11/2024

CERTIFICATE

This is to certify that the following Fire Extinguishers have been tested By us, as per relevant IS specification and Supplied "KENDRIYA VIDYALAYA (BHANDUP)" NCH, DOCKYARD COLONY KANJURMARG(W). We assure That Fire Extinguisher is in good workable Condition One Year from the date of Supply.

REFILLING DUE ON: 15/11/2025

Sr No.	Туре.	Capacity.	Qty.	Test Pressure.	ISI No.	Result
1.	AВC	02 Kg	05 Nos	35 kgf/cm²	IS:2190	OR
1.	ЯВC	04 Kg	05 Nos	35 kgf/cm²	IS:2190	OK
1.	ФСР	05 Kg	01 Nos	30 kgf/cm²	IS:2190	OK,
1.	\mathcal{M}/F	09 Ltr	01 Nos	35 kgf/cm²	IS:2190	OK,
2.	CO2	4.5 Kg	03 Nos	250 kgf/cm²	IS:2190	OK

For SHREE SHIVKRUPA ENTERPRISES

WAAM TO A SOS

Authorized Signature