Government of Bihar

Public Health Engineering Department

Water Quality Test Report

Division Name: Buxar

Sample Collected by :-Kendriya Vidyalya Buxar , Staff.

Date- 22-09-2026

Sl.No	Block	Panchayat	Location	pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	As	Total Coli.	Remarks
1	Buxar	NA	Kendriya Vidyalaya Ramrekhaghat, Buxar	7.0	1	492	320	140	40	22.8	36	128	0.2	2	8	0.2	BDL	Nagative	SAFE
UNIT					NTU	µmho /cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		
Desirable Limit*				6.5-8.5	1		500	200	75	30	250	200	0.3	45	200	1	0.01		
max.permissiable limit				NR	5		2000	600	200	100	1000	600	1.0	NR	400	1.5	NR		

* BDL - Below detection limit.
* NR - Not relaxation.

22/09/26

Chemist
P.H. Division, Buxar

22/09/2026

Assisstant Engineer
P.H. Sub Division, Buxar

S.D.O
P.H. SUB DIVISION
BUXAR