Annexure-C

Appendix-XIII

PEROFORMA FOR SAFE DIRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.:- 1179 **Date:-** 30/07/2026

It is certified that an inspection team headed by **Vishwambhar Kumar Mandal, Assistant Engineer** From **Public Health Sub-division, Samastipur** inspected the **PM SHRI KENDRIYA VIDYALAYA ECR SAMASTIPUR NEAR RAILWAY INDRA STADIUM SAMASTIPUR DISTRICT-SAMASTIPUR, BIHAR, PINCODE-848101** on **30.07.2026** and found that the **PM SHRI KENDRIYA VIDYALAYA ECR SAMASTIPUR** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T Govt.

Signature with Seal.....
30/07/26

Name :- **Vishwambhar Kumar Mandal**

Designation :- Sub Divisional Officer
P.H. Sub. Division, Samastipur

TO,

PRINCIPAL,

PM SHRI KENDRIYA VIDYALAYA ECR SAMASTIPUR NEAR RAILWAY INDRA STADIUM SAMASTIPUR, DISTRICT-SAMASTIPUR, BIHAR, PINCODE-848101

Government of Bihar
Public Health Engineering Department

DISTRICT :- SAMASTIPUR		DIVISION :- SAMASTIPUR											MONTH:-JULY 2026	
S.N.	BLOCK	LOCATION OF SOURCE	PARAMETERS											REMARKS
			pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COLI	
1	SAMASTIPUR	PM SHRI KENDRIYA VIDYALAYA ECR SAMASTIPUR(RO WATER)	7.1	1	114	74	46	12	18	7	52	0.1	-Ve	
Acceptable Limit as per BIS 10500/2012			6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l		-
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012			NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR		-

Soni 30/7/26
Chemist /Lab Assistant
P.H. Division Samastipur

30/07/26
JE
P.H.Sub Division Samastipur

30/07/26
Assistant Engineer
P.H.Sub Division Samastipur

30/07/26
Executive Engineer
P.H. Division Samastipur

Scanned with OKEN Scanner