C18

FORM 'H' FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No F6/DFS/MS/School/2025/NDZ/ 1048 Dated: 22/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **PM Shri Kendriya Vidyalaya** located at **Shahdara, Delhi- 110032**, comprised of **Ground Plus Three Upper Floors** owned/occupied by **PM Shri Kendriya Vidyalaya was issued FSS vide letter no.** F.6/DFS/MS/School/2022/NDZ/1357 dated 27/12/2022. The premises was re-inspected by the officer concerned of this department on 08/08/2025 in the presence **Mrs. Neetu Verma, Principal** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that **the premises is fit for occupancy class "Educational" (Group-B)** with effect from 22/08/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010& also conditions printed below.

Issued on 22/08/2025 at New Delhi by.

22/8/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
O/C

To,

The Principal, PM Shri Kendriya Vidyalaya located at Shahdara, Delhi- 110032

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.