Public Health Engineering Department, Rajasthan
District Laboratory, Jaisalmer

Report of the Chemical Examination of Water

140

2/9/2

To
commandant ,
126bn b s f ramgarh,
126 b n b s f ramgarh.

Reference No : 270144, Dated : 14/08/2026

Date of Receipt : 24/08/2026

District : JAISALMER
Block : SAM
Sample Taker : commandant

Source	Permissible Value as per B.I.S 10500/2012		TW
Location			126 b n b s f hq ram garh
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source	RAMGARH
Village/Town			RAMGARH
Gram Panchayat			RAMGARH
Date of Collection			14/08/2026
Date of Examination			01/09/2026
Sample No			454

Note:- All results except pH are in mg/L

bidity(NTU)	6.5 to 8.5	No relaxation	7.6
our	1	5	Clear
ur	5	15	Colourless
perature	Agreeable	Agreeable	Smell less
Alkalinity	----	----	25
Hardness (as CaCO3)	200	600	120
m (as Ca)	200	600	140
sium (as Mg)	75	200	40
de(as Cl)	30	100	9.76
te(as SO4)	250	1000	60
as(NO3)	200	400	---
	45	45	4.8
	1.0	1.5	0.3
ssolved Solids	500	2000	450
	1.0	No Relaxation	---
Chlorine	0.2	1.0	---

Water is Potable (P)/Unpotable (U)
on (chem)/2026-27/454

वरिष्ठ प्रयोगशाला सहायक
जन.स्वा.अभि.विभाग
प्रयोगशाला—(जैसलमेर)
कोड नं—4757