

District Public Health Laboratory, Parbhani

E-mail ID :- dphlpbn@gmail.com

Phone No. :- 02452/220920

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Dt. Of Coll. :- 01.01.2026

Dt. Of Receipt :- 01.01.2026

Dt. Of Exam. :-

(All The Analytical Results Are In mg/Lit Except pH & Turbidity)

01.01.2026 Onward

Sr. No.	Test Parameter	R.O. Water Sample Kendriya Vidyalaya, (Bramhapuri) Parbhani	BIS Specification No.10500:2012 Normal Values	
			Desirable Limit	Permissible Limit
1	Physical Appearance	Clear, Colourless		
2	Odour	Agreeable	Agreeable	Agreeable
3	Turbidity (as N.T.U.)	0.08	1.0 N.T.U.	5.0 N.T.U.
4	pH	6.6	6.5 To 8.5	No Relaxation
5	Chloride (as Cl)	35	250	1000
6	Nitrate (as CaCo3)	39.10	45	No Relaxation
7	Total Hardness (as CaCo3)	80.00	200	600
8	Alkalinity (as CaCo3)	36.00	200	600
9	Iron (as Fe)	0.02	1.0	No Relaxation
10	Fluoride (as F)	0.11	1.0	1.5
11	Total Dissolved Solids	135.00	500	2000
12	Othe Test (If any)			

*This report is restricted only for the Sample/s is Submitted to this Laboratory.

*This Samples/s is/ are not Collected by this Laboratory

* REMARKS *

A) Sample (No 1) R.O. Water is potable/chemically fit for drinking purpose on the basis of analysed parameters only.

However this water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly.

B) Sample No..... Contain

are more than the desirable limit of BIS Specification No.:10500:2012 For Drinking Water.

However if there is no any other alternate source available near by then this water

source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly.

C) Sample No..... Contains Hence this / these water source/s are chemically unfit for drinking purposes on the basis of analysed parameter only.

Health Services

No.DPHL/PBN/WC-01/CHEM./ 159 /2026

Date :- 08.01.2026

Forwarded with compliments to :

Principal,

Kendriya Vidyalaya, Parbhani (MS)

with reference to letter no.

Nil

Dated - 01.01.2026

Fee Rs :-600 only.

Receipt No.& Dt. :-7143463/01.01.2026

Chief Bacteriologist
Dist. Public Health Laboratory
PARBHANI

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

सन्म/प्रसिद्धि/ जिल्हा आरोग्य प्रयोगशाळा परभणी

दुरध्वनी क्र. (०२४५२) २२०९२०

ईमेल :- dphlpbn@gmail.com

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, प्राचार्य, केंद्रीय विद्यालय, परभणी, ता.जि. परभणी.
पाठविण्याचे पत्र क्रमांक व दिनांक :- / दि. ०१.०१.२०२६

प्रयोगशाळा संदर्भ क्रमांक :- ०२

नमुना घेतल्याचा दिनांक :- ०१.०१.२०२६

नमुना पोहचल्याचा दिनांक :- ०१.०१.२०२६

परिक्षण सुरु केल्याचा दिनांक :- ०१.०१.२०२६

अ. क्र.	नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रती १००मि.ली.नमुन्यातील संभाव्यसुक्ष्मजंतुंची संख्या			
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	ई.कोलाय	
१	आर.ओ.चा पाणी नमुना केंद्रीय विद्यालय, परभणी, ता.जि.परभणी	००	००	००	पिण्यास योग्य

अभिप्राय :- पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरीनची प्रक्रीया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.

पावती क्रमांक :- ७१४३४६३/ रु ३४०/- दिनांक :- ०१.०१.२०२६

अहवाल क्रमांक :- १५०

दिनांक :- ०६.०१.२०२६

अभिप्राय ईमेल/दुरध्वनीद्वारे कळविण्याचा दिनांक :-

NOTE - This Laboratory has not collected the sample/samples. The result of analysis Contained in this report relates only to the sample submitted.

For *Chaitanya R.V.*
मुख्य अणुजीव शास्त्रज्ञ
जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा
परभणी