

BUILDING SAFETY CERTIFICATE

NO.

Dated:

Certified that the existing building Govt. Girls Higher Secondary School at Saraipali comprised of NO basement(s) and NO (upper floors) owned/occupied by Kendriya Vidyalay Saraipali have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Public Works Department on 24.07.2024 in the presence of K.V. Office Staff (Teacher) and that the building/premises is fit for occupancy upto classes X (X/XII) with effect from 01.04.2024 for a period of 01 (One) Years in accordance with rule and subject to compliance of the specific conditions ad appended.

1. It is advised that roof Grading should be done in the entire building, water stagnation at roof can cause spalling of concrete.
2. Repaires to be made as instructed to K.V.office staff during inspection.
3. Drain Outlet Should be installed in Roof.

Issued on 24.07.2024 At Saraipali by

Signature with Seal : _____

Name : A.K.DewanganDesignation : Incharge Sub Divisional OfficerName & Address fo Department/Office: Public Work Department (B/R) Sub Div. Saraipali

कार्यालय अनुविभागीय अधिकारी
लोक निर्माण विभाग (भवन/सड़क), सरायपाली-उपसभाग
जिला - महासमुन्द (छ.ग.)

ज्ञाप क्रमांक

1065/शिल्प

सरायपाली, दिनांक

30/7/24

प्रति,

प्राचार्य
केन्द्रीय विद्यालय
सरायपाली (छ.ग.)

विषय :-

केन्द्रीय विद्यालय सरायपाली को सी.बी.एस.सी. संबद्धता (CBSE Affiliation) जारी रखने हेतु विद्यालय अस्थाई भवन की संरचनात्मक एवं सुरक्षा प्रमाण-पत्र प्रदान करने के संबंध में।

संदर्भ :-

आपका पत्रांक क्र. फ-1-10/केवि-सरायपाली/2024-25/71 दिनांक 10.07.2024।

---00---

उपरोक्त विषयांतर्गत संदर्भित पत्रानुसार चाही गई जानकारी तैयार कर आपकी ओर सादर प्रेषित है।

सहपत्र :-

उपरोक्तानुसार,

o/c

अनुविभागीय अधिकारी
लो.नि.वि.(भ/रा) सरायपाली-उपसभाग
सरायपाली (छ.ग.)