

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1161

Date. 17/07/26

It is certified that an inspection team headed by Mr. KHILESHWAR SAHU S.D.O of Public health Engineer, Saraipali, Mahasamund(C.G), inspected the KENDRIYA VIDYALAYA SARAIPALI on 17.07.26 and found that the "KENDRIYA VIDYALAYA SARAIPALI has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the state GOVT.

The above is valid for a period of July 2027


Assistant Engineer
P.H. Engg. Sub-Division
Saraipali (C.G.)

Signature with seal.....

Name Khileshwar Sahu

Assistant Engineer



Sub Divisional Water Testing Laboratory
Public Health Engineering Department, Sub Div. Saraipali

Near Tahasil office, Saraipali (C.G.) Pin Code-493558

Email ID – ae.phe.saraipali@gmail.com

Test Report (Drinking Water)					
Report no. SDL/PHED/SPL – 44	Discipline:- Chemical Testing	Group:-Drinking water			
Senders name & add पी.एम. केन्द्रीय विद्यालय सरायपाली	Senders letter no./Date	-/13/07/26	Sampled by	Customer	
	DL receipt no.	44	Sampling Plan & procedure	Sampling not done by Lab staff	
	Date of analysis started	14/07/26	DL Receipt date	13/07/26	
			Date of analysis completed	14/07/26	
Sample Details					
S. N.	Sample ID	Block	City / Village	Habitation/Location/Source	
1	44/07/26/379	सरायपाली	सरायपाली	पी.एम. केन्द्रीय विद्यालय सरायपाली	

Details of parameters their test method units and specification as per IS/APHA

S.N	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 (Second Revision) Drinking water		Result of S.No					
		Method	Part no.		Acceptable limit	Permissible limit	1	2	3	4	5	6
1	2	3	4	5	6	7						
1	Chloride as Cl	APHA 23rd ed	4500-Cl-B	mg/L	250	1000	56.18	-	-	-	-	-
2	Total Dissolved solids	APHA 23rd ed	2540-C	mg/L	500	2000	389	-	-	-	-	-
3	Alkalinity as CaCO ₃	APHA 23rd ed	2320-B	mg/L	200	600	140.4	-	-	-	-	-
4	Calcium as Ca ²⁺	APHA 23rd ed	3500-Ca-B	mg/L	75	200	49.89	-	-	-	-	-
5	Magnesium as Mg ²⁺	APHA23rd ed.	3500 Mg-B	mg/L	30	100	23.90	-	-	-	-	-
6	pH	IS:3025	Part-11	pH scale	6.5-8.5	No relaxation	7.40	-	-	-	-	-
7	Turbidity	IS:3025	Part-10	NTU	1	5	0.0	-	-	-	-	-
8	Total Hardness as CaCO ₃	APHA 23rd ed	2340-C	mg/L	200	600	222.88	-	-	-	-	-
9	Taste	IS:3025	Part-8	-	Agreeable	Agreeable	-	-	-	-	-	-
10	Odour	IS:3025	Part-5	-	Agreeable	Agreeable	Agree	-	-	-	-	-
11	Color	APHA23rd ed.	2120-B	Hazen	5	15	2	-	-	-	-	-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. Samples will be stored for a period of 10 days from date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
6. Agreeable is denoted by Agr.

Note - 1. Results apply to the sample as received.

Report Reviewed & approved by

(Tekeshwari Chouhan)
Authorized Signatory