

FIRE SAFETY CERTIFICATE


No. क्रमांक :- न.प.स.मा./अग्नि./2021-22/119

Dated: 08/07/2021

Certified that the KENDRIYA VIDYALAYA SAWAI MADHOPUR (name of the building or premises) at NEAR GOVT. POLYTECHNIC COLLEGE, THINGLA, SAWAI MADHOPUR (address) comprised of GROUND FLOOR basement(s) and FIRST FLOOR (upper floors) owned/occupied by KENDRIYA VIDYALAYA SAWAI MADHOPUR (name of the Institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on (date of inspection) in the presence of RAJESHWAR SINGH, PRINCIPAL (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class I To XII with effect from 08/07/2021 for a period of 07/07/2022 years in accordance with rule and subject to compliance of the conditions.

Issued on 08/07/2021 at 1:20 P.M. by

* Strike out whichever is not applicable.

Signature with Seal : Name : KAPILDesignation : FO / SDM-SOM

To

KENDRIYA VIDYALAYA SAWAI MADHOPURNEAR GOVT. POLYTECHNIC COLLEGE,THINGLA, SAWAI MADHOPUR, RAJASTHAN- 322001.

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)



K.D.R. & COMPANY

FIRE FIGHTING & SAFETY ENGINEERING DIVISION
 A-1, Indira Market, Bazaria, Sawai Madhopur (Raj.) 322 001
 RST/CST No.-08482352781
 Ph., Fax : 07462-224131, Mob : 99802265128
 PAN CARD No.- AVNPP6874E
 E.mail-kdr&company@gmail.com.
 GSTIN: 08AWVPP6874E1ZO

Principal Kendriya Vidhalaya
 Thingla Sawai madhopur
 Rajasthan -322001

Date: 04/08/2018

Handover the system of fire Extinguisher Refilling and Testing Pressure, Supply works completeness.

Dear Sir,

We are pleased informed to you that I shall be handover to complete, installed ABC Type Dry Powder stored Pressure, Co2 fire Extinguisher Refilling and Pressure testing work at your Site. We have competences the system please to take in handover the Refilling and Pressure Testing work of ABC Type Dry Powder Stored Pressure, Co2 Fire Extinguisher system. In regarding the work Summaries are as under:-

Type	Capacity	Year Of Mfg.	Make	Working pressure At 25+2°C KGF/CM2	Pressure Testing/ KGF/CM2	Refilling Date	Inspection date	Due Refilling	Location	Remark	Customer Remark
ABC Stored Pressure	01 kg		Cease Fire	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Principal Room	Satisfy	
ABC Stored Pressure	02 kg		Cease Fire	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Office	Satisfy	
ABC Stored Pressure	02 kg		Cease Fire	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Biology Lab	Satisfy	
ABC Stored Pressure	04 kg		Attack	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Library	Satisfy	
ABC Stored Pressure	04 kg		Attack	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Class IV Out Side	Satisfy	
ABC Stored Pressure	04 kg		Attack	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Biology Lab out Side	Satisfy	
ABC Stored Pressure	04 kg		Attack	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Medical Room	Satisfy	
ABC Stored Pressure	04 kg	2016-2017	Fironil	15 kgf/cm2	23/6/17	4/08/18	4/08/21	School Temple	Satisfy	
ABC Stored Pressure	04 kg	2016-2017	Fironil	15 kgf/cm2	23/6/17	4/08/18	4/08/21	Physics Class Room	Satisfy	
ABC Stored Pressure	04 kg	2016-2017	Fironil	15 kgf/cm2	23/6/17	4/08/18	4/08/21	Chemistry Class Room	Satisfy	
ABC Stored Pressure	04 kg	2016-2017	Fironil	15 kgf/cm2	23/6/17	4/08/18	4/08/21	W. E. Arla	Satisfy	
Co2 Type	4.5 kg		Zenith	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Computer Class Room	Satisfy	
Co2 Type	4.5 kg		Zenith	15 kgf/cm2	4/08/18	4/08/18	4/08/21	Electric Panel Room	Satisfy	

For - K. D. R. & COMPANY

Consultancy, Installation Inspection, Trainer Maintenance, Refilling, Govt. Contractors & Supplier
 Regd. Office : 11/55 Chackchainpura, Sawai Samadhpor (Raj.) 322 001

Principal
 Kendriya Vidyalaya,
 Sawai Madhopur,
 Rajasthan.