Govt. of India भारत सरकार
Executive Engineer, Patna-1 कार्यपालक अभियंता, पटना–1
Central Public Works Department केन्द्रीय लोक निर्माण विभाग
Punaichak, Patna- 23 पुनाईचक, पटना – 23
Telephone No. 0612-2545024 दूरभाष सं० :– 0612- 2545024
Fax No. 0612- 2545158 फैक्स सं० :– 0612- 2545158
E-mail ID- pateepcd.cpwd@gov.in ई–मेल- pateepcd.cpwd@gov.in

पत्र संख्या – **70(119-E)/EE/Patna-1/2025/** 3465 दिनांक 2 /07/2025

सेवा मे,

The Principal
PM Shri Kendriya Vidyalya
Ordnance Factory Nalanda
Rajgir.

विषय:-विघालय का भवन सुरक्षा जॉच कर भवन सुरक्षा प्रमाण पत्र जारी करने के संबंध में।

संदर्भ:- Letter No. 28346/KVKOFN/2025-26/209 dated 22.07.2025

Sir,

The report has been prepared based on the inspection of Kendriya Vidyalaya building on 29.07.2025. The inspection was carried out in the Shri Anjani Kumar, Assistant Engineer-1, & Shri Avinash Chandrapal, Junior Engineer. During the visit, thorough visual assessment of the building's structural components including coloumns, beams and slabs was conducted. It was observed that there are no structural defects or signs of distress in any of the major load-bearing elements. The overall structural framework of the building is found to be in good condition and remains stable. However normal repair and maintenance work is required. Water proofing treatment of roof is also required as seepage of roof during rainy season appears, which may affect structure safety due course to time.

(ई. कृष्ण मोहन कुमार)
कार्यपालक अभियन्ता, पटना–1,
के. लो. नि. वि., पटना।

Scanned with OKEN Scanner