



f 6-7

**भारत सरकार**

केन्द्रीय लोक निर्माण विभाग  
कार्यालय : सहायक अभियन्ता-III  
के.लो.नि.वि., अजमेर (राजस्थान)

दूरभाषा : 0145-2620705

ई-मेल : [ae3acs3@gmail.com](mailto:ae3acs3@gmail.com)

पत्र संख्या:-54(KV-2 Ajmer)/स.अ.-111/2023/ 339

दिनांक : 10/10/2023

संवा में,

✓ श्रीमान् प्राचार्य,  
केन्द्रीय विद्यालय-2,  
के.रि.पु.बल, समूह केन्द्र 2, फॉयसागर रोड,  
अजमेर।

के.वि. नं. 2, अजमेर
प्राप्ति क्रमांक... 1214
प्राप्ति तिथि... 11/10/23
हस्ताक्षर... [Signature]

विषय :- विद्यालय भवन एवं चार दीवारी व स्टाफ क्वार्टरों का संरचनात्मक सुरक्षा प्रमाण-पत्र देने हेतु।

संदर्भ:- Your Letter No. 6-7/के.वि-2/अजमेर/2023-24/116, 118 दिनांक 26/06/2023.

Sir,

With reference to letter under reference on the subject it is certified that the building is visually structurally sound and safe. Subject to the following suggestions required to be followed for up keeping the safety of the building:-

1. Plantation/Gardening near foundation should be avoided, so that seepage of water may not cause damage to foundation and flooring.
2. At terrace/Chajjas and roofs opening of rain water pipes, toilet outlets may be cleaned periodically to avoid seepage/leakage of water through roofs and walls.
3. Proper annual repair and maintenance of building be taken up.
4. This Certificate is valid for One Year from date of issue of this letter.

[Signature]  
Assistant Engineer -III,  
CPWD, Ajmer

Cope to :-The Executive Engineer, CPWD, Ajmer.

[Signature]  
Assistant Engineer-III

[Signature]  
10/10/23