

District Level Water Testing Laboratory P.H.Division, Bettiah

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 19/05/2026 BY Mr. Vivek Shor Duba (Principal) & RECEIVED IN THE LABORATORY ON 19/05/2026

PARTICULARS OF THE SAMPLE					PARAMETERS EXAMINED (VALUE IN MG/L except pH. Otherwise Mentioned)														
Sl. NO	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkanity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	Bettiah	Kumarbagh	Chuhosi	PM SHRI KENDRIYA VIDYALAYA BETTIAH	0.81	7.2	177	70	76	16	5	11	10	0.2	0.0	0.2	118	NT	Neg.
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5-8.5	-	200-600	200-600	75-200	30-100	250-1000	200-400	1.0- NR	45- NR	1-1.5	500-2000	0.01- NR	+VE -VE
Remarks:- Analysed parameters of 11/03/2026 & RECEIVED IN THE LABORATORY ON 11/03/2026																			

Remarks-- Analysed parameters of above sample is within permissible limit.

Signature of the Chemist
19/05/2026

CHEMIST
DLWTL

P.H. Division Bettiah,

