IP: 33197222

Stn Fire Sec
42 Wing AF
C/O 99 APO

42W/2653/3/Org (Fire) (BM) 27 Nov 25

Principal
Kendriya Vidyalaya
Air Force Mohanbari

FIRE SAFETY CERTIFICATE

Sir,

1. It is intimated that Fire Risk Assessment at your school was carried out by the team of Station Fire Section on 04 Jul 25. Following were observed;-

1.1 All classes are having single entry and exit point. In case of fire minimum two possible exit points are required for early evacuation.

1.2 All minor fire fighting appliance available are in serviceable condition.

1.3 Evacuation drill to be practiced at regular interval.

2. Further, Fire risk at school building is low. It is certified that all fire safety measures as defined in IAP 4502 (Manual of Domestic Fire Services) have been adopted and complied with at Kendriya Vidyalaya (Air Force Station Mohanbari) and same have been verified and is hereby confirmed.

3. For information and necessary action, please.

(Harish Kumar)
Flt Lt
Stn Fire Offr

Copy To: Stn Edn Offr