

PRELIMINARY STRUCTURAL SOUNDNESS CERTIFICATE.

Name of Building/Location.

: Kendriya Vidyalaya No. 3 Colaba Mumbai.

Type of Structure


: Permanent


Nature of Inspection

: Visual

Checklist

Sr No	Type of Structure	Particulars	Yes/No	Remarks if any
1.	Substructure	(a) Settlement of Foundation.	No	
		(a) Cracks in beams/column.	No	
		(b) Spalling of concrete.	No	
		(c) Rusting of Reinforcement.	No	
		(d) Sagging/cracks in Balconies, Chajjas, parapets.	No	
2.	Superstructure	(e) Cracks in walls.	No	
		(a) Dampness in external walls.	Yes	
		(b) Leakage/Seepage from roof/toilets.	No	
3.	Functional aspects			
4.	Recommendation	Recommended for further use. This certificate is valid for 01 year from the date of issue.		


JE (Civil)


A GEBR II (NW) Kunjali


GE (NW) Kunjali

Dt: 11 Sep 2024.