

PUBLIC HEALTH ENGINEERING DEPARTMENT

Regional Water Testing Laboratory

District Name : Muzaaffarpur

Month - March 2026

Sample Received on 11.03.2026

Sampling by - Siddhart kumar

Sl. No.	Block	Panchayat	Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	As	T. Coli
1	Mushahani	Nagar Nilgam	31	PM SHRI Kendriya Vidyalaya, Ramna Gannipur	6.97	1.3	451	292	168	32	21.4	59.4	156	0.4	15	BDL	-ve
Acceptable Limit (IS 10500-2012)					6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	0.01mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)					NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	NR	


CHEMIST
 16/3/26
 R.W.T.L. MUZAFFARPUR