

GOVT. OF ASSAM
OFFICE OF THE RANGAPARA FIRE & EMERGENCY SERVICES
STATION SONITPUR, ASSAM.

Memo. No. RANGP/F&ESS/61/240/25

Date: 20.08.25



To

The Principal
Kendriya Vidyalaya Missamari
Sonitpur, Assam. 784506.

Sub:- Fire Safety audit report of PM Shri KV Missamari, Sonitpur Assam.

Sir,

With reference to the above, I have honor to report that an inspection conduct by me on 18.8.25 in your existing school building regarding Fire Safety measures of Kendriya Vidyalaya Missamari School Building during my inspection following particulars are found.

Fire Safety audit details report of the KV school building as follows.

1. Name and address of the school:- PM shri kendriya Vidyalaya Missamari, Sonitpur, Assam.
2. Type of Building:- Permanent Building.
3. Number Block:- 02
4. Height of the Building:- 24 feet.
5. Number of Floor:- a) Block one single floor. b) Block two G+1.
6. Existing Fire Safety system available in the school.
 - a) DCP type extinguishers:- 04.
 - b) ABC type extinguishers:- 15.
 - c) Co2 type extinguishers:- 05.
 - d) Water tank capacity:- 20,000 ltr.

.7, Present Status: Working Condition.

Yours Faithfully


20/8/25
Station Officer
Rangapara Fire & ESS.
Sonitpur Assam
Station Officer .
Rangapara F&ESS
Dist.- Sunitpur (Assam)

Tele : 2806 (Army)
03714-253346 (Civil)
Post – Missamari, Sonitpur
E mail : missasez4-mes@nic.in

Military Engineer Services
Garrison Engineer Missamari
FAX : 03714-253346
Assam, PIN – 784 506

2012/KV/Sat E2 dt 02 Aug 2025

The Principal
PM Shri Kendriya Vidyalaya Missamari
Dist : Sonitpur

SAFETY AND SECURITY CERTIFICATE OF PM SHRI KV MISSAMARI

1. Ref your letter No 1482/111/KVM/2025-26 dt 07 Jul 2025 .
2. It is certified that the building of PM Shri Kendriya Vidyalaya Missamari which was constructed by MES in the year 1978-79 is presently structurally safe and secured as on dated 02 Aug 2025.

(Sanjit Kumar Nongmaithem)
AE (Civ)
AGE (Tech)
for Garrison Engineer

শ্রী জমোতী রংজন
ফাউন্ডেশন (মিহিয়াচাং)
26.08.2025