

Military Engineer Services  
Garrison Engineer Missamari  
FAX : 03714-253346  
Assam, PIN – 784 506

2012/KV/177/E2 dt 13 Feb 2026

The Principal  
PM Shri Kendriya Vidyalaya Missamari  
Dist : Sonitpur

**FWD OF SAFETY AND SECURITY CERTIFICATE OF PM SHRI KV MISSAMARI**

1. Ref your letter No 1482/111/KVM/2025-26/170 dt 09 Feb 2026.
2. A copy of certified in respect of building of PM Shri Kendriya Vidyalaya Missamari is fwd herewith for your info and necessary action please.

  
(Sanjit Kumar Nongmaithem)  
AE (Civ)  
AGE (Tech)  
for Garrison Engineer

**SIB : Report on Structural Audit of KV Missamari**

*Dated: As on 13 Feb 2026*

**Station : KV School Missamari**

| Ser No | Name of Bldg                | Type of Bldg<br>(Temporary/Permanent) | No of Floors<br>(G,G+1,G+2) | Status<br>Occupied/Un occupied<br>(lab /classroom) | Structurally<br>Fit/Unfit | Remarks                                                                   |
|--------|-----------------------------|---------------------------------------|-----------------------------|----------------------------------------------------|---------------------------|---------------------------------------------------------------------------|
| 1      | Class Xi - A                | Temporary                             | G                           | Occupied,classroom                                 | <u>Unfit</u>              | Wooden scantling grid work on false ceiling are deteriorated by termites. |
| 2      | Class X - B                 | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 3      | Class XII - C               | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 4      | Class X - A                 | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 5      | Class XII - A               | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 6      | Class XII - B               | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 7      | Class XI - C                | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 8      | Class XI - B                | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 9      | Class IX - B                | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 10     | Class IX - A                | Temporary                             | G                           | Occupied,classroom                                 | Fit                       |                                                                           |
| 11     | Table Tennis Room -1 (Boys) | Temporary                             | G                           | Occupied                                           | Fit                       |                                                                           |
| 12     | Table Tennis Room -2(Girls) | Temporary                             | G                           | Occupied                                           | Fit                       |                                                                           |

*dy*

*dy*

*dy*

|    |                     |           |   |                     |       |                                                            |
|----|---------------------|-----------|---|---------------------|-------|------------------------------------------------------------|
| 13 | NCC Office          | Temporary | G | Occupied            | Fit   |                                                            |
| 14 | Class VII - B       | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 15 | Humility Room       | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 16 | Class VI - B        | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 17 | Class VII - B       | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 18 | Store Room          | Temporary | G | Occupied, store     | Fit   |                                                            |
| 19 | Class VIII - A      | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 20 | Class VI - B        | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 21 | Class VIII - B      | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 22 | store -1            | Temporary | G | Occupied            | Fit   |                                                            |
| 23 | store -2            | Temporary | G | Occupied            | Fit   |                                                            |
| 24 | store -3            | Temporary | G | Occupied            | Fit   |                                                            |
| 25 | Scout Room          | Temporary | G | Occupied            | Fit   |                                                            |
| 26 | Physical Education  | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 27 | Work Education dept | Temporary | G | Occupied, classroom | Fit   |                                                            |
| 28 | Library             | Permanent | G | Occupied, library   | Unfit | Structural cracks observed on roof slab.                   |
| 29 | Art Studio          | Permanent | G | Occupied, classroom | Unfit | Structural cracks observed on roof slab.                   |
| 30 | Drinking water area | Permanent | G | Occupied            | Unfit | Leakages on ceiling due to structural cracks on roof slab. |
| 31 | Physics lab         | Permanent | G | Occupied, lab       | Unfit | Leakages on ceiling due to structural cracks on roof slab. |


ds

by

tnh

|    |                                  |           |     |                             |       |                                                                                             |
|----|----------------------------------|-----------|-----|-----------------------------|-------|---------------------------------------------------------------------------------------------|
| 32 | Chemistry lab                    | Permanent | G   | Occupied, lab               | Unfit | Leeakges on ceiling due to Strctural cracks on roof slab, Reinforcement exposed on ceiling. |
| 33 | Computer lab                     | Permanent | G   | Occupied, lab               | Unfit | Leeakges on ceiling due to strctural cracks on roof slab in corridor.                       |
| 34 | Biology lab                      | Permanent | G   | Occupied, lab               | Unfit | Leeakges on ceiling due to strctural cracks on roof slab in corridor.                       |
| 35 | Principal Room                   | Permanent | G   | Occupied, Office accn       | Fit   |                                                                                             |
| 36 | CVSC Room                        | Permanent | G   | Occupied, office accn       | Unfit | Leeakges on ceiling due to strctural cracks on roof slab, Reinforcement exposed on ceiling. |
| 37 | Exam Dept Room                   | Permanent | G   | Occupied, office accn       | Unfit | Wall seepages, Reinforcement exposed.                                                       |
| 38 | Waiting Room                     | Permanent | G   | Occupied, office accn       | Unfit | Leeakges on Ceiling due to Strctural Cracks on roof slab, Reinforcement exposed on ceiling. |
| 39 | Staff Room-1                     | Permanent | G   | Occupied, office accn       | Unfit | Leeakges on Ceiling due to Strctural Crack on roof slab, Reinforcement exposed on ceiling.  |
| 40 | Staff Room-2                     | Permanent | G   | Occupied, office accn       | Fit   |                                                                                             |
| 41 | Kendriya Vidyalaya Primary Block | Permanent | G+1 | Occupied, class Room 1 to V | Fit   |                                                                                             |

Note: It is recommended that immediate structural repair be carried out for the buildings declared unfit. This office i.e., GE Missamari shall not be held liable for any unforeseen.

  
JE (Civil)

  
Rakesh Kumar  
AE (Civil)  
ACE B/R - I

  
(Ankur Gupta, DSE)  
EE (SG)  
Garison Engineer