



Mobile No.: 9422806693
9850906693

NAVBHARAT FIRE SAFETY SERVICES

Plot No. 62, Block No. 6, Shivaji Nagar, Nagpur -10
Email.:navbharatfire.safety@gmail.com

Ref.No. NFSR/2026/KV

Date: 07.03.2026

TO WHOM SO EVER IT MAY CONCERN

This is to certify that the following fire extinguishers of Kendriya Vidyalaya Jawahar nagar Bhandara are tested and refilled by us on 07/03/2026 and are due on 06/03/2027.

SR NO	TYPE AND CAPACITY OF FIRE EXTINGUISHERS	QTY	QUANTITY PASSED	QUANTITY REJECTED	TOTAL WORKING
1	WATER CO ₂ 9LTRS CAP	6 NOS	5 NOS	1 NO	5 NOS
2.	FOAM TYPE 9 LTRS CAP	1 NO	NIL	1 NO	NIL
3	CO ₂ 2 KG CAPACITY	2 NOS	2 NOS	NIL	2 NOS
4	ABC TYPE 6KG	8 NOS	8 NOS	NIL	8 NOS

The above fire extinguishers are maintained as per IS:2190 LATEST.

This is for your information and record.

Navbharat Fire Safety Services

VINAYAK JOSHI

PROPRIETOR