SHREE FIRE
WHERE SAFETY IS PRIORITY

SHREE FIRE ENGINEERS

DESIGNING | ENGINEERING | INSTALLATION | CONSULTANCY

CERTIFICATE NO: -SFE/25-26/ HT-265
DATE: - 20/08/2025

TO,
KENDRIYA VIDYALAYA
GANDHINAGAR

SUBJECT:HYDRO TESTING OF FIRE EXTINGUISHERS.

DEAR SIR,

THIS IS TO CERTIFY THAT; **SEVEN (07)** NOS ABC TYPE FIRE EXTINGUISHERS. CYLINDER LOCATED AT **KENDRIYA VIDYALAYA GANDHINAGAR,** HAVE BEEN CLEANED AND HYDRAULICALLY PRESSURE TESTED AT **35 kg/cm² AS PER IS 2190:2010** BY US. THE TEST REVEALED NO SIGN OF ANY CRITICAL LEAKAGE AND PERMANENT STRETCH. NO CORROSION OBSERVED INSIDE THE CYLINDER.

DETAILS OF THE CYLINDER ARE GIVEN BELOW.

SR. NO.	TYPE	CAPACITY	QUANTITY	HYDRAULIC TESTING	REMARKS
1.	ABC TYPE FIRE EXTINGUISHERS	6.0 KG	07 NOS	35 kg/cm2	PASS

NEXT DUE DATE: 08.2028

SIGNATURE OF SUPERVISOR

SHREE FIRE ENGINEERS

SHREE FIRE ENGINEERS

D-517, Ganesh Glory 11, off. SG Highway, Jagatpur, Ahmedabad-382470
Branches : Bhuj, Gandhidham, Mundra, Rajkot, Surat, Mumbai.
PH : +91 98795 75029 | Email : info@shreefire.co.in | www.shreefireengineers.com

SHREE FIRE
WHERE SAFETY IS PRIORITY

SHREE FIRE ENGINEERS

DESIGNING | ENGINEERING | INSTALLATION | CONSULTANCY

CERTIFICATE FOR REFILLING OF FIRE EXTINGUISHERS

CERTIFICATE NO: -SFE/25-26/ REF-117
DATE:- 20/08/2025

TO,
KENDRIYA VIDYALAYA
GANDHINAGAR

DEAR SIR,

THIS IS TO CERTIFY THAT THE FOLLOWING FIRE EXTINGUISHERS ARE REFILLING BY US AND THEY FOUND TO BE IN GOOD WORKING CONDITION.

SR.NO.	TYPE OF FIRE EXTINGUISHERS	CAPACITY	QUANTITY	DATE
1.	ABC TYPE FIRE EXTINGUISHERS	6.0 KG	07 NOS	20.08.2025
2.	CO2 TYPE FIRE EXTINGUISHERS	4.5 KG	04 NOS	20.08.2025

NEXT REFILLING DATE: - 19.08.2026

THIS CERTIFICATE IS VALID FOR A PERIOD OF 12 MONTHS

SHREE FIRE ENGINEERS

D-517, Ganesh Glory 11, off. SG Highway, Jagatpur, Ahmedabad-382470
Branches : Bhuj, Gandhidham, Mundra, Rajkot, Surat, Mumbai.
PH : +91 98795 75029 |Email : info@shreefire.co.in |www.shreefireengineers.com