



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services

First Floor of Midnapur Fire Station Sepoy Bazar, P.O.: Medinipur, P.S.: Kotwali, Pin:- 721101

Memo No.: FSR/211862506300013856

Date : 14-08-2025

From :
Divisional Fire Officer
Paschim Medinipur
West Bengal Fire & Emergency Services

To :
P M Shri Kvno2 Kharagpur
KENDRIYA VIDYALAYA 2, KHARAGPUR, AT-RAILWAY SATTLEMMENT, P.O-721301

Sub: Fire Safety Recommendation for an existing and proposed Central Government school establishment comprising 04 nos. block i.e. BLOCK- Admin & Secondary block (G+II), BLOCK- F & P block (G+I), BLOCK- Middle block (G+I) as existing and BLOCK- Laboratory block (Single storied) as proposed, under group of Educational occupancy in the name & style of " KENDRIYA VIDYALAYA NO.- 2" Jhapetapur, south side, Kharagpur, Dist.- Paschim Medinipur, PIN- 721301, W.B.

This is in reference to your AIN 211862506300013856 dated 04-Jun-2025 regarding Fire Safety Recommendation for an existing and proposed Central Government school establishment comprising 04 nos. block i.e. BLOCK- Admin & Secondary block (G+II), BLOCK- F & P block (G+I), BLOCK- Middle block (G+I) as existing and BLOCK- Laboratory block (Single storied) as proposed, under group of Educational occupancy in the name & style of " KENDRIYA VIDYALAYA NO.- 2" Jhapetapur, south side, Kharagpur, Dist.- Paschim Medinipur, PIN- 721301, W.B.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

Recommendation :

A. CONSTRUCTION :

1. The whole construction of the existing building shall be carried out as per approved plan drawings conforming the relevant building rules of local Body.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.

B. OPEN SPACE & APPROACH:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862506300013856