STAFF MINUTE SHEET

From : Officer-in-Charge, SHO
प्रभागीय अधिकारी, स्था स्वा सं

227/15/SHO
INS Valsura/ भा नौ पो वलसुरा
Jamnagar/ जामनगर

To : EXO/कर्थव्य कार्यपाल अधिकारि

23 Aug 24

Copy to : CTS, GE (N), AGE (E&M), KV School
क.त.से, जि ई (नौ), ए.जि.ई (ई & एम),
केंद्रीय विद्यालय

BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER FOR THE MONTH OF AUG 24

Bacteriological Examination of drinking water for the month of Aug 24 from various locations were carried out at XL laboratory Jamnagar on 16 Aug 24. The report of the same is enclosed herewith.

(ललित कुमार शर्मा / Lalit Kumar Sharma)
सर्जन कमांडर / Surgeon commander
प्रभागीय अधिकारी/Officer-in-Charge

Encl: As above

To,
The Officer-in-charge,
INS VALSURA
Indian Coast Guard Station Valsura
JAMNAGAR-361150

Excellence with Quality
Diagnostics
Next to Dr.Ruparelia Hospital,
Near Gurudhwara,I.G.Marg, Jamnagar-361008 .
Phone No-0288-2661718. For Home visit -9054044353

Date :21-08-2024

MICROBIOLOGICAL ANALYSIS OF WATER

WATER SAMPLES FROM	Coliform Count MPN/ml	CATEGORY
Pump House No.1(RO PLANT)	0	A
Ward Room (RO PLANT)	0	A
Trishul Galley	0	A
Sailors Institute	0	A
Central Galley	0	A
Leading 88(RO Plant)	0	A
DSC Galley	0	A
Kendriya Vidhyalaya	1	B
SMA Market(RO Plant)	1	B

Comments :

Water samples from.

1	*Pump House No.1(RO PLANT)*	*Excellent.*
2	*Ward Room (RO PLANT)*	*Excellent.*
3	*Trishul Galley*	*Excellent.*
4	*Sailors Institute*	*Excellent.*
5	*Central Galley*	*Excellent.*
6	*Leading 88(RO Plant)*	*Excellent.*
7	*DSC Galley*	*Excellent.*
8	*Kendriya Vidhyalaya*	*Acceptable.*
9	*SMA Market(RO Plant)*	*Acceptable.*

Mean Count / 100 ml	Category	Comments
0	A	**Excellent**
1 - 10	B	**Acceptable** But make regular sanitary checks.
10 - 50	C	**Unacceptable** Poor maintainence Disinfect source.
More than 50	D	**Grossly polluted** Look for alternative source or disinfect source.

Lalit Kumar Sharma
Surgeon Commander

Dr. Tejal P. [illegible]