OFFICE OF THE SUPERINTENDING ENGINEER:RWSS DIVISION:BERHAMPUR
Near Jarada Bunglow, Pin – 760004, Ph. 0680-2296344
eerwss_bam@nic.in rwssbam@gmail.com

No. 111 (lab) /dt 04.05.2024

To

The Principal,
Kendriya Vidyalaya,Gopalpur Militry Station,
Golabandha, Ganjam(odisha), pin-761052.

Sub : Water Quality Test Report of Kendriya Vidyalaya Gopalpur Militry Station, Golabandha.

Ref: Your good office Ltr No.15029/KV-GMS/1167/2024-25/07 Dtd.01.05.2024

Sir,

With reference to the water sample submitted by you at District Water Testing Laboratory, Berhampur, the following Parameters are tested.

Sl.No.	Parameter	Units	Permissable Limit	Testing Value	
				Tap water	Aqua guardwater
1	Alkalinity	Mg/ltr	600	340.0	24.0
2	Chloride	Mg/ltr	1000	144.0	28.0
3	Fluoride	Mg/ltr	1.5	0.846	0.562
4	Total Hardness	Mg/ltr	600	280.0	12.0
5	Iron	Mg/ltr	1.0	0.106	0.062
6	pH	--	6.5-8.5	8.12	7.28
7	Elec.Conductivity	(µmho/cm)	--	1194.7	124.6
8	TDS	Mg/ltr	2000	776.55	80.6
9	Turbidity	NTU	5	1.38	0.41
10	Bacteriology(Total Coliform& E.Coli)	MPN/100ml	Absent (0)	Absent (0)	Absent (0)

Water is safe for Drinking because testing values are under permissible limit.

Yours faithfully,

04.05.24

Executive Engineer(RWSS)

4.5.2024

Attested