


02 B - 11

Commercial Complex, Ranjeet Nagar, New Delhi- 110008
 Phone 011 - 25700168, 9099554242
 Email : dwtl@watersupermart.com • www.delhiwatertestlab.com



analysis report



Delhi
**WATER & GENERAL
 TEST LAB (P) Ltd.**




AN
 ISO 9001 : 2008
 COMPANY

TEST CERTIFICATE

Test certificate No: DWGTL/23-24/167 C				Issue Date: 22/01/2024	
Party Name/company's name: Principal KV Sec-24, Noida				Ref. No.: Nil	
Date of collection: 22/01/2024				Protocol Used: IS:10500-2012	
Sample Collected by: Party		Types of water: Water Sample		Lab code: DWGTL/23-24/167 C	
				Testing Duration : 22/01/2024	
S.N	Parameters	Units	Test results	Requirements	Test method Used
1.	Sulphate as SO ₄	mg/l	20.2	200	IS:3025 Pt-24-2009
2.	Total Dissolved Solids (Pure Water)	mg/l	116	500	IS:3025 Pt-16-2003
3.	Total Hardness	mg/l	24	200	IS:3025 Pt-21-2009
4.	Total Dissolved Solids (Raw Water)	mg/l	2307	500	IS:3025 Pt-16-2003

G. Singh
 Checked By



Authorized Signatory

WE UNDERTAKE TESTING OF : WATER * AIR * EFFLUENTS * MATERIALS

The above result are related only to the sample. Endorsement of products is neither inferred nor implied, this report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special written permission. Samples will be destroyed after 15 days from the date of reporting unless otherwise specified.

Total liability of laboratory is limited to the invoiced amount

Approved by the Municipal Corporation of Delhi (Health Deptt)