

Tele: 6461

Garrison Engineer (South)
Military Engineer Services
Kalyan Marg, Bani Park
Jaipur 302 006

2367/KV-02/250 /E2 dt 22 Jul 2026

Principal
K V No 2
Jaipur Mil Stn

ISSUANCE OF BUILDING SAFETY CERTIFICATE FOR THE SCHOOL BUILDING

1. Please ref your letter No 49/KV 2/Jaipur/2025-26/145 dt 30 Apr 2026.
2. Building Safety Certificate as asked vide your ibid letter under ref is fwd herewith for your info and necessary action pl.



(Shruti Patil)
Lt Col
Garrison Engineer (S)

Encl: (As above)

PRELIMINARY STRUCTURAL SURVEY

1. Building : Vidyalaya Main Building/Administrative Block
2. Type of Bldg : Permanent
3. Year of Construction :
4. Mode of Inspection : Visual
5. Date of Preliminary Structural Survey : 25 May 2026

Checklist

Ser No			Yes / No	Remarks
1.	Substructure	(a) Settlement of foundation	No	The use of bldg. may be continued with Regular Maintenance.
2.	Superstructure	(a) Cracks in beams/column	No	
		(b) Spalling of concrete	No	
		(c) Rusting of reinforcement	Not visible from outside	
		(d) Sagging/cracks in balconies, chajjas, parapets.	No	
		(e) Cracks in walls	No Major cracks	
3.	Functional aspects	(a) Dampness in external walls	No	
		(b) Leakage/seepage from roof/toilets	No	
4.	Recommendation	Routine periodic maintenance is required to keep the building in a serviceable condition.		


(JE (Civil))


(AGE B/R-III)


(GE (South) Jaipur)