OFFICE OF THE DEPUTY COMMANDANT
CENTRAL INDUSTRIAL SECURITY FORCE
(MINISTRY OF HOME AFFAIRS)

UNIT: CTPS CHANDRAPURA
Dated - 02 / 09/2025

No:E-42099/CISF/CTPS(C)/FIRE/STORE/43/2025- 913

To,
The Principle
Kendriye Vidyalaya,
DVC CTPS Chandrapura

Sub: FIRE SAFETY CERTIFICATE: REG

Kindly refer to KV School CTPS Chandrapura Ref. 40029/केवि चदपुरा / 1159 / 2024--25 PB-134 Dated 12.08.2025 on the subject cited above.

02. In this regard, it is hereby informed that on 01.09.2025 CISF Fire Wing Prevention team carried out periodic inspection of all First Aid Firefighting Equipment installed at school campus and found following observation in respect of fire safety: -

I) Kendriya Vidyalaya, Chandrapura is having existing building comprising of ground & one upper floor.
II) Accessibility of Fire Tender up to Kendriya Vidyalaya is available.
III) The details of deployment of First Aid Firefighting Equipment are as under.

- CO2 Extinguishers (Capacity -02 kg) :- 05 Nos
- CO2 Extinguishers (Capacity -3.2 kg) :- 01 No
- CO2 Extinguishers (Capacity -4.5kg) :- 07 Nos.

IV) One underground water static tank having capacity of about 30,000 Litres is available inside the premises.

V) During checking all the installed Fire extinguishers are found in working condition.

Kydav 04/09/25
DY. COMMANDANT/FIRE
CISF UNIT CTPS CHANDRAPURA
DY. COMMANDANT/FIRE
CISF Unit CTPS Chandrapura