OFFICE OF THE SUPERINTENDING ENGINEER:RWSS DIVISION:BERHAMPUR
Near Jarada Bunglow, Pin – 760004, Ph. 0680-2296344
eerwss_bam@nic.in rwssbam@gmail.com

No. 914 /dt 10/09/2026

To

The Principal PM Shri Kendriya Vidyalaya Brahamapur
Ganjam Odisha , Pin - 760011

Sub : Water Quality Test Report of Regular Tap Water.

Ref: F.No. 150112 /PM SHRI KV BAM/2026-27 Dtd.18.08.2026

Sir,

With reference to the water samples submitted by you at District Water Testing Laboratory, Berhampur, the same has been tested for the following Parameters.

Sl.No.	Parameter	Units	Permissible Limit	Testing Value
				Regular Tap Water
1	Alkalinity	Mg/ltr	600	172.0
2	Chloride	Mg/ltr	1000	44.0
3	Fluoride	Mg/ltr	1.5	0.560
4	Total Hardness	Mg/ltr	600	148.0
5	Iron	Mg/ltr	1.0	0.061
6	pH	--	6.5-8.5	7.05
7	Elec.Conductivity	(µmho/cm)	--	375
8	TDS	Mg/ltr	2000	243.75
9	Turbidity	NTU	5	2.7
10	Bacteriology(Total Coliform& E.Coli)	MPN/100ml	Absent (0)	Absent (0)
11	Tempertaure	Celsius (°C)	--	25.1

Water is safe for Drinking as the testing values are under permissible limit.

Yours faithfully,

10/9/26

CEO-cum-Executive Engineer(RWSS)

Chief Executive Officer
-cum-
Executive Engi...
District Water Testing ...ory
RWSS Division, Berha...

OFFICE OF THE SUPERINTENDING ENGINEER:RWSS DIVISION:BERHAMPUR
Near Jarada Bunglow, Pin – 760004, Ph. 0680-2296344
eerwss_bam@nic.in rwssbam@gmail.com

No. 273 /dt 10/09/2026

To

The Principal PM Shri Kendriya Vidyalaya Brahamapur
Ganjam Odisha , Pin - 760011

Sub : Water Quality Test Report of Filtered Water.

Ref: F.No. 150112 /PM SHRI KV BAM/2026-27 Dtd.18.08.2026

Sir,

With reference to the water samples submitted by you at District Water Testing Laboratory, Berhampur, the same has been tested for the following Parameters.

Sl.No.	Parameter	Units	Permissible Limit	Testing Value
				Filtered Water
1	Alkalinity	Mg/ltr	600	180.0
2	Chloride	Mg/ltr	1000	28.0
3	Fluoride	Mg/ltr	1.5	0.516
4	Total Hardness	Mg/ltr	600	172.0
5	Iron	Mg/ltr	1.0	0.039
6	pH	--	6.5-8.5	7.02
7	Elec.Conductivity	(µmho/cm)	--	372
8	TDS	Mg/ltr	2000	241.8
9	Turbidity	NTU	5	2.0
10	Bacteriology(Total Coliform& E.Coli)	MPN/100ml	Absent (0)	Absent (0)
11	Tempertaure	Celsius (°C)	--	25.1

Water is safe for Drinking as the testing values are under permissible limit.

Yours faithfully,

10/9/26

CEO-cum-Executive Engineer(RWSS)

10/09/26

Chief Executive Officer
-cum-
Executive Engineer
District Water Testing Laboratory
RWSS Division, Berhampur