

**Madhya Pradesh housing & Infrastructure Development Board,
Division Ratlam**

Safety Certificate

It is Certified that the Kendriya Vidhyalay Bhawan At A.F.S. Makarpura Baroda has been Constructed by the M.P. Housing Board During the year 2003 - 2005.

The School Building And Staff Quarters of Campus Constructed as per R.C.C. Structural Design Approved by the I.I.T. Delhi and Design is checked to the earth quake Resistant as per the provision of I.S. 1893 - 2002 and I.S. 13920 - 1993 hence Building is safe for further Construction if done as per approved Design. During the Construction all Safety Measure has been taken.


Executive Engineer
Madhya Pradesh Housing &
Infrastructure Development Board,
Division Ratlam



भारत सरकार
GOVT. OF INDIA
केन्द्रीय लोक निर्माण विभाग
CENTRAL PUBLIC WORKS DEPTT.



कार्यपालक अभियंता का कार्यालय/Office of the Executive Engineer
वडोदरा केन्द्रीय मंडल, डाक बंगला/Vadodara Central Division, Dak Bungalow,
फतेहगंज सर्कल, वडोदरा / Behind Post Office Fatehgunj, Vadodara-390 002
दूर भाष (0265)2784241, Fax-2787144, email : eeecd.cpwd@gov.in

No: 23(92)/VCD/2022/97 2-120

Date : 05/10/2022

सेवा/में,
The Principal,
Kendriya Vidyalaya
No.3, Airforce Station
Makarpura,
Vadodara-390014 (Gujarat)

विषय:- Issue of Safety and Security certificate for Vidyalaya Building and
Vidyalaya Staff Quarters.


संदर्भ : 1) Your letter No. F.120112/2022-23/KV/Makar/10 dtd.26.08.2022
and email dated 08.09.2022.

महोदय,

In reference to your above mentioned email, the Vidyalaya building and
Vidyalaya Staff quarters were inspected by the Assistant Engineer, BCSD, CPWD,
Vadodara on 14.09.2022. He reported that on the basis of visual observation all the
structure of school building and staff quarters are in good condition and no major
structural defects were noticed during inspection.

However, the detailed investigation regarding structural soundness may be
carried out after conducting Non-Destructed Tests (NDT) by means of specialized
equipments, such as rebound hammer, pulse velocity and other tests etc. from IIT(s),
NIT(s) or any Govt. Engineering Colleges, as this office is not having the facility for
the same and then actual stability and soundness of member may be ascertained.

The testing as mentioned above may be done after getting separate sanction
from the competent authority of KVS.


कार्यपालक अभियंता
वडोदरा केन्द्रीय मंडल
के.लो. नि.वि. वडोदरा

Copy to :

- 1) The Superintending Engineer, GCC, CPWD, Gandhinagar for information please.
- 2) The Assistant Engineer, BCSD, CPWD, Vadodara for information w.r.t. his letter
No. 80(85)/BCSD/2021/104-H dated 04.10.2022.

कार्यपालक अभियंता