

केन्द्रीय विद्यालय नं 3

वायुसेना स्थल , मकरपुरा
वडोदरा - ३९००१ (गुजरात)
दूरभाष : (०२६५) २६४३८०८
CBSE School No. 14095
E-mail: kvafsbaroda@gmail.com



Kendriya Vidyalaya No.3

Air Force Station, Makarpura
Vadodara- 390014 (Gujarat)
Phone: (0265) 2643808
CBSE Affiliation No. 400021
Website: no3baroda.kvs.ac.in

No. F.120370/2025-26/KV AFS MKP /


Dated: 21.07.2025

DECLARATION REGARDING FIRE PROTECTION SYSTEM

We hereby declare that our school (KV No.3 AFS Makarpura, Vadodara) building / educational building is situated at Makarpura, Near Air Force Station Makarpura , Vadodara.

We hereby declare that our building height is 8.5 Meter which is not Above-9 Meters. So fire NOC is not required as per URBAN DEVELOPMENT AND URBAN HOUSING DEPARTMENT Notification Number GH/V/9 of 2021/AGN- 102021-100-L-1. Date:- 22 January -2021, However for the fire safety purpose we have strictly followed the requirement of NATIONAL BUILDING CODE OF INDIA PART-4 FIRE AND SAFETY, We have provided in our building Fire Protection System as mentioned below which is as per requirement of NATIONAL BUILDING CODE OF INDIA PART-4 RELETED TO FIRE SAFETY.

1. ABC Types 06kg (10 Numbers)
2. CO2 types 4kg (05 Number)
3. Water CO2 (9L) 02 Number
4. Two water Tank capacity (20000 L)


प्राचार्य / PRINCIPAL
केन्द्रीय विद्यालय / Kendriya Vidyalaya
वायु सेना स्थल, मकरपुरा / AFS, Makarpura
वडोदरा-390014 / Vadodara-390014
गुजरात / Gujarat

Signature with stamp



WE SERVE TO SAVE

રાજ્ય અગ્નિ નિવારણ સેવાઓની કચેરી

બ્લોક નં.૧૩, ત્રીજો માળ, ડૉ.જીવરાજ મહેતા ભવન, ગાંધીનગર-૩૮૨૦૧૦.

ઈ-મેલ: dir.sfps@gmail.com, ટેલિફોન નં.૦૭૯-૨૩૨-૫૭૦૨૨/૨૩/૪૦.

ક્રમાંક: સફસ/ફન- ૮૫.૧/૨૪૮/૨૦૨૧

તા.૦૫/૦૬/૨૦૨૧

વિષય:- ફાયર સેફ્ટી સર્ટિફિકેટ ઈશ્યુ કરવા બાબત સ્પષ્ટતા થવા બાબત.

પરિપત્ર:-

સરકારશ્રી દ્વારા ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક (સુધારા) નિયમો, ૨૦૨૧ ની ત્રીજી અનુસૂચિ મુજબનાં બિલ્ડીંગો માટે નિયમ -૨૩(૧) ની જોગવાઈ મુજબ ફાયર સેફ્ટી સર્ટિફિકેટ (ફાયર NOC) ઈશ્યુ કરવાની જોગવાઈ થયેલી છે. વખતોવખત રાજ્યના રીજીયનલ ફાયર ઓફીસર/ચીફ ફાયર ઓફીસર સાથે મીટીંગો દરમિયાન ક્ષેત્રિય કક્ષાએ કામગીરી દરમિયાન ફાયર NOC ઈશ્યુ કરવા મામલે અમૂક મુશ્કેલીઓ અનુભવાય છે. જેથી આ બાબતે સ્પષ્ટતા કરવી જરૂરી બને છે.

શૈક્ષણિક સંસ્થાઓનાં કિસ્સામાં જે ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક(સુધારા) નિયમો, ૨૦૨૧ ની ત્રીજી અનુસૂચીમાં જણાવ્યાનુસાર ૯ મી ઉંચાઈ અને/ અથવા ૫૦૦ચો.મી. કોઈ એક કે વધુ માળનાં ક્ષેત્રફળથી ઓછાં ઉંચાઈ/ક્ષેત્રફળનાં કિસ્સામાં શૈક્ષણિક સંસ્થા દ્વારા ફાયર સેફ્ટી સર્ટિફિકેટ લેવાની જોગવાઈ સંદર્ભે વિશેષ સ્પષ્ટતા કરતા જણાવવાનું કે, જે શૈક્ષણિક સંસ્થા ૯ મીટર કે તેથી વધુ ઉંચાઈ ધરાવતી હોય તેમજ એમા જો બેઝમેન્ટ હોય તો એનું ક્ષેત્રફળ ૨૦૦ ચો.મીથી વધુ હોય તેવા કિસ્સામાં જ સંબંધિત ફાયર અધિકારી પાસેથી જ ફાયર સેફ્ટી સર્ટિફિકેટ નિયમોનુસાર મેળવવાનું રહે છે. આ સિવાયના કિસ્સાઓમાં કે જેમાં શૈક્ષણિક સંસ્થા કે જેની ઉંચાઈ ૯ મીટરથી ઓછી હોય તેવા કિસ્સામાં ફ્લોર એરિયા ધ્યાને લીધા સિવાય એવી શૈક્ષણિક સંસ્થાનાં સંચાલકે ફાયર-સેફ્ટી અંગેની જરૂરી વ્યવસ્થા શૈક્ષણિક સંસ્થા દ્વારા કરી એ મતલબનું સેલ્ફ સર્ટિફિકેશન કરી એવું સર્ટિફિકેટ મંજૂરી આપનાર ઓથોરીટીને મોકલી આપવાનું રહેશે. આ ૯ (નવ) મીટરથી ઓછી ઉંચાઈ વાળી તમામ પ્રકારની શૈક્ષણિક સંસ્થાઓ માટે આ સાથે સામેલ ચેક લીસ્ટ મુજબની વ્યવસ્થા કરી શૈક્ષણિક સંસ્થાનાં સંચાલકે પ્રમાણપત્ર સહ શૈક્ષણિક સંસ્થાને મંજૂરી આપનાર

ઓથોરીટીને મોકલી આપવાની રહે છે. દરેક જીલ્લામાં શિક્ષણ વિભાગનાં નિરીક્ષકશ્રી કે અન્ય અધિકૃત અધિકારી દ્વારા પણ આ ચેક લીસ્ટ મુજબ વખતો-વખત ચકાસણી કરવાની રહેશે.



નિયામક

રાજ્ય અગ્નિ નિવારણ સેવાઓ,
ગાંધીનગર.

નકલ સવિનય રવાના-

1. અધિક મુખ્ય સચિવશ્રી, શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગ, ગાંધીનગર.
2. અગ્ર સચિવશ્રી, શિક્ષણ વિભાગ, ગાંધીનગર.
3. સચિવશ્રી, શિક્ષણ વિભાગ, ગાંધીનગર.
4. ઉચ્ચ શિક્ષણ કમિશ્નરશ્રી, ગાંધીનગર.
5. કમિશ્નરશ્રી(શૈક્ષણિક સંસ્થાઓ), ગાંધીનગર.
6. પ્રાથમિક શિક્ષણ નિયામકશ્રી, ગાંધીનગર.
7. નિયામકશ્રી, ટેકનિકલ શિક્ષણની કચેરી, ગાંધીનગર.
8. કમિશ્નરશ્રી, મ્યુનિસિપાલીટીઝ એડમીનીસ્ટ્રેશનની કચેરી, ગાંધીનગર.
9. કમિશ્નરશ્રી, મહાનગરપાલીકા- અમદાવાદ, ગાંધીનગર, સુરત, વડોદરા, રાજકોટ, જામનગર, જુનાગઢ, ભાવનગર.
10. રીજીયોનલ મ્યુનિસિપલ કમિશ્નરશ્રી, અમદાવાદ, ગાંધીનગર, ભાવનગર, સુરત, વડોદરા, રાજકોટ.

નકલ રવાના:-

1. જિલ્લા શિક્ષણ અધિકારીશ્રી, તમામ.
2. રીજીયોનલ ફાયર ઓફિસરશ્રી, વડોદરા, ગાંધીધામ, રાજકોટ, ગાંધીનગર, સુરત.
3. ચીફ ફાયર ઓફિસરશ્રી, મહાનગરપાલિકા- અમદાવાદ, ગાંધીનગર, સુરત, વડોદરા, રાજકોટ, જામનગર, જુનાગઢ, ભાવનગર.



સત્યમેવ જયતે

The Gujarat Government Gazette

EXTRAORDINARY

PUBLISHED BY AUTHORITY

Vol. LXII]

FRIDAY, JANUARY 22, 2021 / MAGHA 2, 1942

Separate paging is given to this Part in order that it may be filed as a Separate Compilation.

PART IV-B

Rules and Orders (Other than those published in Parts I, I-A, and I-L) made
by the Government of Gujarat under the Gujarat Acts

URBAN DEVELOPMENT AND URBAN HOUSING DEPARTMENT

Notification

Sachivalaya, Gandhinagar, 22nd January, 2021.

No.GH/V/9 of 2021/AGN-102021-100-L1 - WHEREAS the circumstances exist which renders it necessary to amend the Gujarat Fire Prevention and Life Safety Measures Rules, 2014;

AND WHEREAS circumstances exist which renders it necessary for the State Government to dispense with the power conferred by sub-section (1) of section 57 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013;

NOW THEREFORE in exercise of the powers conferred by section 57 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 read with section 14 of the Gujarat Fire Prevention and Life Safety Measures (Amendment) Ordinance, 2021 (Guj. Ord. No. 3 of 2021), the Government of Gujarat hereby makes the following rules further to amend the Gujarat Fire Prevention and Life Safety Measures Rules, 2014, namely:-

1. (1) These rules may be called the Gujarat Fire Prevention and Life Safety Measures (Amendment) Rules, 2021
- (2) They shall come into force on the date of their publication in the Official Gazette.
2. In the Gujarat Fire Prevention and Life Safety Measures Rules, 2014 (hereinafter referred to as "the said Rules"), in rule 2, for sub-rule (2), the following sub-rule shall be substituted, namely:-

"(2) The words and expressions not defined in these rules but defined in the Act, or GDCR or National Building Code of India or relevant Indian Standards or Specifications published by Bureau of Indian Standards shall have the meanings as assigned to them in the Act or GDCR or National Building Code of India or relevant Indian Standards or Specifications published by the Bureau of Indian Standards for construction and fire safety of buildings or premises and pandals."

3. In the said Rules, for rule 4, the following new rule shall be substituted, namely:-

"4. Equipment and Appliances for Fire Service

- (1) The Chief Fire Officer in Municipal Corporation area and the Director in other areas of the State shall determine the requirement of equipment and appliances for rescue, firefighting, personal protection in such numbers and with such specifications taking into consideration the apprehension of fire risk in their area for effective measures of safety and efficient response in times of emergency. The Chief Fire Officer shall submit the report in this regard to the Director every year.
- (2) The Chief Fire Officer in Municipal Corporation area and the Director in other areas of the State, with the previous sanction of the Government, shall procure equipment and appliances determined under sub-rule (1) in such manner that each fire division is adequately equipped to meet with the requirement of fire-fighting and fire safety measures and make all necessary arrangements for their upkeep and maintenance to ensure their availability to provide fire prevention and fire safety service as and when required.
- (3) The life of equipment and appliances may be as per the recommendations of the Standing Fire Advisory Council of the Ministry of Home Affairs, Government of India or of any other authority as may be authorized by the Government for this purpose."

4. In the said Rules, in rule 5, -

- (i) for sub-rule (1), the following new sub-rule shall be substituted, namely:-

"(1) The Chief Fire Officer in Municipal Corporation area and the Director in other areas of the State, shall identify the area where the establishment of a fire station is tactically advantageous to provide fire prevention and life safety measure."

- (ii) for sub-rule (4), the following new sub-rule shall be substituted, namely:-

"(4) The composition of the fire station alongwith the staff pattern and facilities to be provided by a fire station may be decided by the Chief Fire Officer in Municipal Corporation area and the Director in other area, depending upon the circumstances prevailing and apprehension of fire risk in the area."

5. In the said Rules, for rule 9, the following new rule shall be substituted, namely:-

"9. Eligibility for Licensed Agency. -No person or association of persons shall be eligible to apply for grant of license to act as a Licensed Agency unless he,-

- (a) possesses atleast any of the following qualifications, namely:-

(i) Bachelor's or Master's degree in Fire or Fire & Safety or Fire & Environment, Health and Safety; or Fire Engineering from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); or

(ii) Advanced Diploma or Diploma or Certificate in Fire Engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or by the Gujarat State Institute for Fire Safety Training (GSIFST), Government of Gujarat or by the Gujarat Institute of Disaster Management (GIDM), Government of Gujarat; or

(iii) Post Graduate Diploma or Post Diploma in Fire or Fire & Safety or Fire & Environment, Health & Safety; or Fire Engineering; or Industrial Safety or Industrial Safety & Health from a University established or incorporated by an Act of the Parliament or a State Act in India or from an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); or

- (1) The licence shall be—
 - (a) non-transferable,
 - (b) valid for two year from the date of issue, unless suspended or cancelled earlier,
 - (c) renewable for period of two years, if so desired, before expiry of the licence.
 - (2) Changes, if any, in respect of
 - (a) partners, director and/or members,
 - (b) address of the office of the Licensed Agency,shall be forthwith reported to the Authority issuing the licence.
 - (3) The Licensed Agency shall always keep the work, executed or being executed by it, open for inspection by the Director or the Regional Fire Officer or Chief Fire Officer or any fire officer authorised by the Director or the Regional Fire Officer or the Chief Fire Officer.
 - (4) The Licensed Agency shall have office / branch in the State of Gujarat."
7. In the said Rules, for rule 14, the following new rule shall be substituted, namely:-
- "14. **Certificates to be issued by a licensed agency.**-(1) A certificate regarding the compliance of the fire prevention, life safety and fire protection measures in a building or a part thereof as specified in the THIRD SCHEDULE, may be issued by a Licensed Agency in "Form-B1".
- (2) During the period of validity of the Fire Safety Certificate i.e. from the date of issuance till the first renewal of the same, the Licensed Agency shall give an annual declaration in "Form-B2" stating that the fire prevention, life safety and fire protection measures provided in the building or premises are operational, in good repair and efficient condition as specified in sub-section (2) of section 29 of the Act. This declaration shall be submitted to the Regional Fire officer or the Chief Fire officer not later than 15 days every year on completion of first and second year from the date of issue of fire safety certificate."
8. In the said Rules, for rule 21, the following new rule shall be substituted, namely:-
- "21. **Appointment of Fire Safety Officer.**-(1) For the purpose of effective fire prevention, life safety and fire protection measures during the occupancy of the building and to get the fire safety certificate renewed, every owner or occupier shall appoint a fire safety officer, two months prior to expiry of fire safety certificate issued under section 21, having prescribed qualifications, experience and training and thereafter shall send the compliance report to that effect in "Form-B11" to the Regional Fire Officer or the Chief Fire Officer.
- (2) Fire safety officer shall be enrolled by the Director after successful completion of the prescribed training and shall be issued the enrolment certificate in "Form-B12".
- (3) In case of failure to appoint a fire safety officer as specified in sub-rule (1), the Regional Fire Officer or the Chief Fire Officer shall, if it is considered to do so, communicate to the relevant authority to take appropriate action for the discontinuance of the use or closure of the building or premises or part thereof, as the case may be.
- (4) The classification of buildings or premises, the qualifications, experience, type of training and duties of different categories of the Fire Safety Officer shall be as specified in the FOURTH SCHEDULE."

15. In the said Rules, for rule 32, the following new rule shall be substituted, namely:-

"32. Training Charges.- The trainees including Fire Safety Officers, shall pay at the time of admission, training charges as notified by the State Government, to the Principal, Gujarat State Institute for Fire Safety Training (GSIFST):

Provided that, the trainees on the roll of State Fire Service shall not be liable to pay training charges."

16. In the said Rules, in rule 37, for the words "after the institution of prosecution by the officer specified in column (2)", the words "after the institution of prosecution by the officer specified in column (1)" shall be substituted.

17. In the said Rules, for the FIRST SCHEDULE, the following schedule shall be substituted, namely:-

FIRST SCHEDULE

(See Rule 3)

Qualifications for the appointment of Nominated Officer

No person shall be eligible for the appointment as Nominated Officer unless he/she possesses atleast any of the following qualifications, namely:-

- (i) Bachelor's or Master's degree in Fire or Fire & Safety or Fire & Environment, Health & Safety; or Fire Engineering from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act 1956 (3 of 1956) with the experience of two years; or
- (ii) Advanced Diploma or Diploma or Certificate in Fire Engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or by the Gujarat State Institute for Fire Safety Training (GSIFST), Government of Gujarat or by the Gujarat Institute of Disaster Management (GIDM), Government of Gujarat with the experience of three years; or
- (iii) Post Graduate Diploma or Post Diploma in Fire or Fire & Safety or Fire & Environment, Health & Safety; or Fire Engineering, or Industrial Safety or Industrial Safety & Health from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act 1956 (3 of 1956) with the experience of three years; or
- (iv) Fellow (FFireE) or Member (MFFireE) or Graduate (GFFireE) of the Institution of Fire Engineers (U.K.) or the Institution of Fire Engineers (India) with the experience of three years.

18. In the said Rules, in the SECOND SCHEDULE, -

(i) in para 1, in the Table, in the entry at serial no. 2, in column (2), for the words "Chief Fire Officer", the words "Regional Fire Officer / Chief Fire Officer" shall be substituted;

(ii) in para 2, for sub-para (2), the following sub-para shall be substituted, namely:-

"(2) The staff car used by the Regional Fire Officer or the Chief Fire Officer may display on the bonnet a flag made out of blue black blazer cloth and star plate on front and rear side bumper of the staff car as per drawing."

19. In the said Rules, for the existing THIRD SCHEDULE and FOURTH SCHEDULE, the following schedules shall be substituted, namely:-

"THIRD SCHEDULE*(see sub-rule (1) of rule 14)***List of buildings requiring fire safety certificate**

Following is the list of buildings requiring fire safety certificate for compliance of the fire prevention, life safety and fire protection measures:-

- (a) All high rise buildings having height 15 m and above; and
- (b) special buildings, those are,
 - (1) hotel, educational, institutional, business, mercantile, storage, hazardous and mixed occupancies buildings, where any of these buildings have floor area more than 500 m² on any one or more floors;
 - (2) educational buildings having height of 9 m and above;
 - (3) institutional buildings having height of 9 m and above;
 - (4) all assembly buildings;
 - (5) all multilevel car parking;
 - (6) industrial buildings (ANNEXURE B of NBC-2016 Part 4);
 - (i) Light Hazard - having height of 15 m and above
 - (ii) Moderate hazard - covered area more than 500 m²
 - (iii) High hazard - covered area more than 50 m²
 - (7) all hazardous buildings;
 - (8) buildings, having area more than 300m² of incidental assembly occupancy on any floor;
 - (9) buildings with two basements or more, or with one basement of area more than 500 m².

NOTE:

- 1) The definitions and terminology of the terms mentioned in this schedule shall be as per the NBC - 2016 (Part 4).
- 2) Institutional buildings include hospitals, nursing homes, sanatoria, custodial, penal and mental institutions with beds (with or without ICU).
- 3) Industrial buildings having occupancy classified as light hazard as per ANNEXURE B of NBC-2016 (Part 4) below 15 m height of any floor area shall be covered under the provisions of the Factories Act, 1948 and the Rules made thereunder.
- 4) Owner or occupiers of the building or premises not covered under this schedule are advised to provide fire fighting installations as mentioned in Table 7 of the NBC - 2016 (Part 4) in good faith and practice and maintain the same in operational conditions all time.

FOURTH SCHEDULE

(see sub-(4) of rule 21)

Classification of Buildings, qualification, experience and type of training for Appointment of Fire Safety Officer

1. The Fire Safety Officers of different Grades shall be appointed for different class of buildings namely:

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
1	1. Residential buildings (other than hotels and guest houses) having height more than 15 m but not exceeding 35 m.	FSO – G (Fire Safety Officer – General)	Bachelor's or Master's degree in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering	0 year	Basic Course in Fire Prevention, Life Safety and Fire Protection
	2. Hotels upto 15 m in height (floor area exceeding 500 m ² but not more than 1000 m ²).		OR Bachelor's degree in- Architecture; or Chemical or Civil or Electrical or Mechanical Engineering	0 year	
	3. Educational buildings having height more than 9 m but not exceeding 15 m.		OR		
	4. Hospitals and Nursing Homes with beds having height less than 15 m with plot area upto 1000 m ² .		Post Graduate Diploma or Post Diploma in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering; or Industrial Safety or Industrial Safety & Health	0 year	
	5. Custodial, Penal & mental institutions less than 10 meters in height.				
	6. Assembly buildings less than 10 meters in height upto 300 persons, or above 10 meter but not exceeding 15 meter in height.				
	7. Business buildings above 15 m but not exceeding 24 m in height.				

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	8. Mercantile occupancies less than 15 m in height and Ground + one storey or more, having total floor area more than 500 m ² . 9. Light Hazard category industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having height 15m and above. 10. Moderate Hazard category Industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having covered area more than 500 m ² and upto 1000 m ² . 11. Mixed Use Occupancies having height more than 9 m upto 15 m. 12. buildings with two basements or more, or with one basement of area more than 500 m ² .				
2	1. Residential buildings (other than hotels and guest houses) having height more than 35 m but not exceeding 60 m in height. 2. Hotels upto 15 m in height (floor area more than 1000 m ²). 3. Hotels 15m and above but not exceeding 30 m in height.	FSO – A (Fire Safety Officer – Advance)	Advanced Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed MIFireE exam of Institution of Fire Engineers OR Diploma in fire	0 year 0 year	Advanced Course in Fire Prevention, Life Safety and Fire Protection

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	4. Educational buildings having height more than 15 m but not exceeding 30 m in height.		engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed GFireE exam of Institution of Fire Engineers.		
	5. Hospitals and Nursing Homes with beds having height less than 15 m with plot area more than 1000 m ² , or those having height above 15 m upto 24 m.		OR Certificate in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India	5 years as sub-officer and above	
	6. Custodial, Penal & mental institutions more than 10 m but not exceeding 24 m in height.		OR Bachelor's or Master's degree in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering	2 year	
	7. Assembly buildings less than 10 m in height having more than 300 persons, or above 15 m but not exceeding 24 m in height.		OR Post Graduate Diploma or Post Diploma in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering; or Industrial Safety or Industrial Safety & Health	3 years	
	8. Business buildings above 24 m but not exceeding 30 m in height.		OR Bachelors degree in- Architecture or Chemical or Civil or Electrical or Mechanical Engineering	3 years	
	9. Mercantile occupancies above 15 m in height but not exceeding 30 m in height.				
	10. Moderate Hazard category Industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having covered area more than 1000 m ² .				
	11. Storage buildings below 15 m in height and				

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	covered areas more than 250 m ² , Ground floor or Ground plus more than one floor. 12. Mixed Use Occupancies having height more than 15 m upto 30 m.				
3	1. Residential buildings (other than hotels and guest houses) having height more than 60 meters. 2. Hotels exceeding 30 m in height. 3. All Starred Hotels. 4. Hospitals and Nursing Homes which exceed 24 m but not exceeding 45 m in height. 5. Custodial, Penal & mental institutions more than 24 m but not exceeding 30 m in height. 6. Assembly buildings above 24 m in height but not exceeding 30 m in height, shopping malls and underground and elevated mass rapid transit systems. 7. Business buildings above 30 m in height. 8. Underground Shopping centre. 9. High Hazard category Industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having covered area more than 50 m ² . 10. Multilevel Car Parking.	FSO – S (Fire Safety Officer – Specialist)	Advanced Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed MIFireE exam of Institution of Fire Engineers OR Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed GFireE exam of Institution of Fire Engineers OR Certificate in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India OR Bachelor's or Master's degree in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering OR	5 years 8 years 10 years as sub-officer and above 5 years	Specialised course in Fire Prevention, Life Safety and Fire Protection

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	11. Hazardous building upto 15 m in height, single storey or more than one storey.		Post Graduate Diploma or Post Diploma in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering; or Industrial Safety or Industrial Safety & Health	7 years	
	12. Mixed Use Occupancies having height more than 30m.				
	13. Buildings covered under SCHEDULE THREE but not mentioned specifically in this column.		OR Bachelor's degree in- Architecture or Chemical or Civil or Electrical or Mechanical Engineering	7 years	

Note:

1. Unless specified otherwise, the minimum educational qualification shall be from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956).
 2. Work experience, wherever applicable, shall be in field of Fire Prevention, Life Safety and Fire Protection measures, Fire systems design/ installation, Fire safety consultancy and Fire related inspections/ audits.
 3. FSO-A can also take up work of renewal of fire safety certificate for type of buildings mentioned against FSO-G.
 4. FSO-S can also take up work of renewal of fire safety certificate for type of buildings mentioned against FSO-A and FSO-G.
- 2. The duties of the fire safety officer shall be:-**
1. Issue fire safety certificate renewal upon compliance of all the mandatory requirements.
 2. Give bi-annual declaration that fire prevention, life safety and fire protection measures provided in the building or premises are operational, in place and in efficient working condition.
 3. Carry out bi-annual emergency mock drills and maintain record of the same. During the mock drill, provide basic information to occupiers and other security/maintenance staff with respect to basic fire prevention, fire-fighting and related aspects.
3. Mode and format of providing training to persons for being eligible to enroll as FSO shall be as notified by the State Government from time to time."

By order and in the name of Governor of Gujarat,

R. H. VASAVA,
Deputy Secretary to Government.

