

Tele: AF/7870

Ministry of Defence
Military Engineer Services
Garrison Engineer (AF) Tezpur
PO: Salonibari
Assam : 784104

2456/18-19/KV/ 136 /E2

18 Jun 2024

✓ Kendriya Vidyalaya-2
AF Station Tezpur

SAFETY CERTIFICATE

1. Please ref your letter No 1499-118/KVAFT-2/2023-24/67 dt 07 Jun 2024.
2. With reference to the above subject, visual inspection has been carried out. The building as per visual inspection seems safe for occupation. However, the points observed and photos attached as per **Appendix 'A'**. These points needs to be rectified on priority to avoid any incident in future works services may be initiated for the same:-
 - (a) Roof slab seepage and leakage of some places.
 - (b) Crack on Boundary wall, Near gate No 02.
 - (c) External plaster required at many places.
3. For detailed structural survey consultancy from a specialised agency needs to be carried out, funds for the same may be deposited so that detailed consultancy can be carried out at earliest.
4. This is for your info and necessary action please.

Encls :- (As above)

(Rajesh Anandawat)
Capt

Offg Garrison Engineer (AF)

affie
for record
for
20/6/24