

Pimpri Chinchwad Municipal Corporation

Pimpri, Pune-411018.

Phone: 020-67331110/1120

Fax: 020-27425600

E-Mail: commissioner@pcmcindia.gov.in

Web: www.pcmcindia.gov.in

NO ws/lab/1765/2023

Date 07/04/2023

The Principal,

Kendriya Vidyalay,

C.M.E Pune.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Kendriya Vidyalay, C.M.E Pune, on Date: 03/04/2023 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1762/2023 dated 05/04/2023 & ws /lab /1759/2023 dated 3/04/2023 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.

Kendriya Vidyalaya, CME Pune-31.

Chief Chemist

Pimpri Chinchwad Municipal Corporation

Pimpri-18

प्राचार्य/PRINCIPAL

के वी सी एम ई KVCME

पूना Pune

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(w/s) DIVISION

No-WS/LAB/62/20 23

Date 05/04/2023

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

DATE OF EXAMINATION-4/09/2023

NAME- केंद्रिय विद्यालय

ADDRESS- C.M.E Pune

SOURCE –

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE(PPM)	CONCLUSION MPN/100 ml		REMARK
			Coliforms	E.Coil	
1	water sample	Nil	0/100 ml	-	Potable

CHIEF CHEMIST Water Treatment Plant Pimpri Chinchwad Municipal Corp. Nigdi, Pune 44

प्राचार्य PRINCIPAL

के बी सी एम ई पुणे ,KV CME Pune

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION

Report Of Chemical Examination Of Water

NAME. केंद्रिय विद्यालय C.M.E. ADDRESS - पुणे.

NO-WS/LAB/59/2023.

DATE - 03/04/2023.

DATE OF RECEIPT - 03/04/2023.

DATE OF EXAMINATION-03/04/2023.

SOURCE : RO Water.

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit
1	Turbidity	1 N.T.U Max	0.52 NTU
2	pH	6.5 to 8.5	7.91
3	Total Hardness	200 mg/lit	56 mg/lit
4	Chloride	250 mg/lit	12 mg/lit
5	Calcium	75 mg/lit	11-22 mg/lit

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

प्राचार्य/PRINCIPAL

के वी सी एम ई /KVCME

पुणे / Pune

CHIEF CHEMIST Water treatment plant sector 23 Nigdi