

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Cantboard/2026/spn

Dated: 26.08.2026

It is certified that an inspection team headed by

ANMOL AGNIHOTRI, SANITARY. (Name of Officers with designation)
INSPECTOR

from CANTONMENT BOARD, SHAHJAHANPUR PHED

inspected the PM SHRI KENDRIYA VIDYALAYA No. 2 OCF SHAHJAHANPUR

(Name & Address of the school) on 25.08.2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. AGSS/WT/26082500020

dated 26.08.2026 of AGSS Analytical And Research lab (PHED Lab)
(P) LTD, Delhi

certified that the

PM Shri Kendriya Vidyalaya (Name of school) has safe drinking water
No. 2 OCF Shahjahanpur

facilities for the students and members of staff of the institution. School is also maintains
the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 26.08.2027

Signature with Seal:

Name

Designation

Name & Address of the Office/ Department

Harshita
Chief Executive Officer
Cantonment Board
Shahjahanpur

To

PM SHRI KENDRIYA VIDYALAYA
No. 2 OCF SHAHJAHANPUR (U.P.) - 242001
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



AGSS ANALYTICAL AND RESEARCH LAB (P) LTD.

(Accredited as per ISO/IEC 17025 : 2017, Recognised by FSSAI, MoEF&CC and Directorate of Ayush)

C-37/2, 2nd, 3rd & 4th Floor, Lawrence Road, Industrial Area, Delhi-35

Ph.: 011-45022985, 9311654060

E-mail: agsslabs@gmail.com, support@agsslabs.com Web.: www.agsslabs.com



Certificate No. TC-14844

CIN : U73200DL2016PTC300483 GST : 07AAOCA4142Q1Z6

Format No.: AGSS/QS/F-024

TEST REPORT

Page No.: 1 of 1

Issued to : Anmol Agnihotri Northern Railway Shahjahanpur	ULR No. : TC148442600047635F Report No. : AGSS/WT/26082500020 Sample Issue Date : 25/08/2026 Report Issue Date : 26/08/2026
---	--

Name of The Product	: Water (Ground)	Sample Received Date	: 25/08/2026
Product Description	: Clear Colourless Liquid	Analysis Starting Date	: 25/08/2026
Batch No./Lot No.	: NA	Analysis Completion Date	: 26/08/2026
Date of Manufacturing	: NS	Date of Sampling	: -
Date of Expiry	: NS	Quantity Received	: 1 Ltr.
Packing Condition	: Plastic Bottle	Environment Condition	: Ok
Location	: OCF KV. No-2 PM SHRI SPN 01 No.	Sampling Method	: NA
Sample Received / Collected By	: Customer	Sampling By	: NA
Testing Required	: Microbiological Test		
Others specification	: Sample Code-01/SI/Cannt./SPN/2026		

TEST RESULT

S.No.	Test Parameters	Units	Results	Requirement as per IS:10500:2012		Method of Testing
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
1	E. coli	per 100ml	Absent	Absent	NA	IS:15185:2016


Remarks : The tested sample conforms to IS:10500:2012, with respect to above test only.

End of Report



For Report Verification

Preeti Sudan
Microbiologist
Checked by



Sooraj Gautam
Microbiologist
Authorized Signatory



Scan to check Scope
of Accreditation

NOTE : (1) The laboratory accepts the responsibility for content of report. (2) The above result pertain only to the sample tested and applicable parameters. (3) Test report shall not be reproduced except in full, without written approval of the laboratory. (4) This test report shall not be reproduced wholly or in part and can not be used as an evidence in the court of law without written approval of M/S AGSS. (5) The sample will be stored up to 21 days from the date of issue of test certificate unless otherwise specified. (6) Sample not drawn by M/S AGSS Lab, unless specified in report. (7) All disputes are subject to the Delhi jurisdiction.