भारत सरकार
Government of India
केन्द्रीय लोक निर्माण विभाग
CENTRAL PUBLIC WORKS DEPARTMENT
कार्यपालक अभियंता का कार्यालय
OFFICE OF THE EXECUTIVE ENGINEER
आइजोलकेन्द्रीय मंडल, सी.पी.डब्लू.डी., जोमुआनविला, प्रथमतल, चौलमुन, आइजोल–796009(मिजोरम)
AIZAWL CENTRAL DIVISION, CPWD, ZOMUAN VILLA, 1ST FLOOR, CHAWLHHMUN,AIZAWL-796009(MIZORAM)

No. 54(22)/ACD/2025-26/ 31 Dated: 08/09/2025

To ,

The Principal
KendriyaVidyalaya
Project PushpakZemabawk,
Aizawl (Mizoram) – 796017

Subject: Structural Safety & Stability Certificate of Vidyalaya Building, Staff Quarters and Boundary Wall of Kendriya Vidyalaya Project Pushphak, Zemabawk, Aizawl.

Reference No: F.1856/2025-26/211 Dated:28.07.2025

Dear Sir,

With reference to your letter on the above cited subject, this is to certify that the Permanent School Building, Staff Quarters, and Boundary Wall of Kendriya Vidyalaya were inspected by the undersigned along with the concerned Assistant Engineer on 15.08.2025 and **It is Certifed that the permanent School Building and Staff Quarters are apparently seems to be safe.**

· However, **some portions of the boundary wall are not structurally sound and safe** and some portion of the wall even collapsed due to absence of any protective measures like Retaining wall etc. on the down side of the premises.

· It is **recommended that renovation of the boundary wall and retaining wall may be carried out at the earliest** to ensure structural safety and stability of the school building.

08.09.2025
Executive Engineer
Aizawl Central Division
CPWD, Aizawl - 796009

27/7/26
प्राचार्य / PRINCIPAL
पीएम श्री केन्द्रीय विद्यालय
PM SHRI KENDRIYA VIDYALAYA
आइजोल (मिजोरम)–796017
Aizawl (Mizoram)-796017

अध्यक्ष / Chairman
वि.प्र. समिति पीएम श्री केन्द्रीय विद्यालय
V.M.C. PM SHRI Kendriya Vidyalaya
आइजोल (मिजोरम)–796017
Aizawl (Mizoram)-796017

Scanned with OKEN Scanner