




GOVERNMENT OF MIZORAM
OFFICE OF THE EXECUTIVE ENGINEER
SEWERAGE & DRAINAGE AIZAWL EAST DIVISION
PUBLIC HEALTH ENGINEERING DEPARTMENT
Tuikhuahtlang, Aizawl, Mizoram - 796001
E-mail: eephedsnd@gmail.com



No. 8-TB/2022-EE(S&D)/PHE/77

Dated Aizawl, the 13th July, 2026

Certificate for Safe Drinking Water and Sanitation Condition

It is to certified that an Inspection headed by Mr. Henry Lalrinzawna, Sub-Divisional Officer from Sewerage & Drainage Aizawl East-II Sub-Division, Public Health Engineering Department, Aizawl, Mizoram Inspected the PM SHRI Kendriya Vidyalaya Aizawl, Project Pushpak, Zemabawk, Aizawl, Mizoram - 796017 on 09th July, 2026 and on the basis of Water Test Report (Attached) bearing No.VL/LB/2026-2027/216 Dated 09th July, 2026 of State Referral Institute (SRI), PHE, Govt. of Mizoram (PHED, Lab.,) certified that the PM SHRI Kendriya Vidyalaya Aizawl, Project Pushpak, Zemabawk, Aizawl, Mizoram has Safe Drinking Water facilities for the students and members of staff of the Institution.

School is also maintained safe and hygienic Sanitation Condition in the school building and the campus as per norms prescribed by the Central / State / UT Government.

This Certificate is valid till 1 (one) year.

Signature with Seal

Name :

LALMUANKIMA

Designation :

Executive Engineer, PHED

Name and Address :
of the Office/
Department

Sewerage & Drainage Aizawl East Division
Executive Engineer, PHE
Public Health Engineering Department
Sewerage & Drainage
Government of Mizoram
Aizawl East Division
Tuikhuahtlang, Mizoram - 796001

प्राचार्य / PRINCIPAL
पीएम श्री केन्द्रीय विद्यालय
PM SHRI KENDRIYA VIDYALAYA
आइजोल (मिजोरम)-796017
Aizawl (Mizoram)-796017

अध्यक्ष / Chairman
वि.प्र. समिति पीएम श्री केन्द्रीय विद्यालय
V.M.C. PM SHRI Kendriya Vidyalaya
आइजोल (मिजोरम)-796017
Aizawl (Mizoram)-796017



(SRI), Government of Mizoram
Khuahltlang, Mizoram - 796001
Tel : 0389-2322601, Fax : 0389-2321604

STATE REFERRAL INSTITUTE



Name & Address of the Customer

PM Shri Kendriya Vidyalaya
Project Pushpak, Thuampui,
Aizawl
Contact :- 7501701063

TEST REPORT

Report No. : VL/LB/2026-2027/216
Report Date : 09.07.2026
Sample ID : SRI2627216
Date of Receipt of Sample : 09.07.2026
Date(s) of Performance : 09.07.2026
Reference No. & Date :

We hereby Certify that the following sample submitted to the Laboratory has been analysed with the following results :

1	Source & Place of Sampling	Kendriya Vidyalaya School Tui
2	Sample Mark (if any, given by the customer)	-
3	Name of Sample Collector	R. Lalrinchhana, JE, PHED
4	Date of Sampling of the Customer	09.07.2026
5	Description of Sample (As declared by customer)	For commercial purpose
6	Environmental conditions during testing	Temp 23.3°C & RH 75%

N.	Characteristics	B.I.S Specification for drinking IS-10500 : 2012		Method of Test	Results
		Acceptable Limit	Permissible Limit		
1	pH at 23.3°C	6.5-8.5	-	APHA 24th Ed.2023, 4500 H-B	7.64
2	Total Dissolved Solids (in mg/l)	500.0	2000.0	APHA 24th Ed.2023 2540 C	62.00
3	Conductivity (in µmho/cm)	500.0	1500.0	APHA 24th Ed.2023, 2510 B	123.7 at 25.1°C
4	Colour	5.0	15	APHA 24th Ed.2023 2120 B	5
5	Odour	Agreeable	Agreeable	IS: 3025 (Part 5) : 1983	Agreeable
6	Taste	Agreeable	Agreeable	APHA 24th Ed.2023, 2160 C	Agreeable
7	Turbidity (in NTU)	1.0	5.0	APHA 24th Ed.2023, 2130 B	0.02
8	Total Alkalinity as CaCO ₃	200.0	600.0	APHA 24th Ed.2023, 2320 B	36.00
9	Total Chloride	250.0	1000.0	APHA 24th Ed.2023 4500-Cl- B	17.00
10	Total Hardness	300.0	600.0	APHA 24th Ed.2023, 2340 C	46.00
11	Calcium as Ca	75.0	200.0	APHA 24th Ed.2023, 3500-Ca B	12.02
12	Magnesium as CaCO ₃	30.0	100.0	APHA 24th Ed.2023, 3500-Mg B	3.89

Disclaimer :

The results relate only to the item(s) tested as received.

This Test Report shall not be reproduced except in full, without the permission of State Referral Institute, PHED.

The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.

The laboratory is responsible for all the information given in the report.

Reviewed by

(LALHRIATZUALI RENTHLEI)

Quality Manager
State Referral Institute
(State Laboratory)
PHED, Mizoram



***** End of report *****

Authorised by

(LALHRIATZUALI RENTHLEI)

Quality Manager
State Referral Institute
(State Laboratory)
PHED, Mizoram



STATE REFERRAL INSTITUTE

PHED (SRI), Government of Mizoram
Tui khuahtlang, Mizoram - 796001
Tel : 0389-2322601, Fax : 0389-2321604

Name & Address of the Customer

PM Shri Kendriya Vidyalaya
Project Pushpak, Thuampui,
Aizawl
Contact :- 7501701063

TEST REPORT

Report No. : VL/LB/2026-2027/216
Report Date : 09.07.2026
Sample ID : SRI2627216
Date of Receipt of Sample : 09.07.2026
Date(s) of Performance : 09.07.2026
Reference No. & Date :

We hereby Certify that the following sample submitted to the Laboratory has been analysed with the following results :

1	Source & Place of Sampling	Kendriya Vidyalaya School Tui
2	Sample Mark (if any, given by the customer)	-
3	Name of Sample Collector	R. Lalrinchhana, JE, PHED
4	Date of Sampling of the Customer	09.07.2026
5	Description of Sample (As declared by customer)	For commercial purpose
6	Environmental conditions during testing	Temp 23.3°C & RH 75%

SN.	Characteristics	B.I.S Specification for drinking IS-10500 : 2012		Method of Test	Results
		Acceptable Limit	Permissible Limit		
1	Iron	1.0	1.0	Palm Test	0.02 mg/l

Disclaimer :

- The results relate only to the item(s) tested as received.
- This Test Report shall not be reproduced except in full, without the permission of State Referral Institute, PHED.
- The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.
- The laboratory is responsible for all the information given in the report.

Reviewed by

(LALHRIATZUALI RENTHLEI)

Quality Manger

Quality Manager
State Referral Institute
(State Laboratory)
PHED, Mizoram



Authorised by

(LALHRIATZUALI RENTHLEI)

Quality Manger

Quality Manager
State Referral Institute
(State Laboratory)
PHED, Mizoram

***** End of report *****