1193
27/01/21

28

OFFICE OF THE DEPUTY FIRE OFFICER
BALASORE CIRCLE BALASORE

FORM-V
FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No-74/2019 BLS CLE

Certificate No-07/BLS CLE Dt-19.01.2021

This certificate is valid up to **-18.01.2023**
(Apply for renewal at least three months before expiry)

Certified that G+2 Floors Kendriya Vidyalaya, over plot No-08/1191 & 08/1215, Khata No-101, Mouza-Mahuldiha, Rairangpur, Dist-Mayurbhanj was inspected by officers of Odisha Fire Service team on 25.11.2019 and re-inspected on 18.01.2021 in presence of the Principal, Kendriya Vidyalaya, Rairangpur, Dist-Mayurbhanj and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019. Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

G Floor-	--- usage---	Class room, Chemistry lab, store, teacher, staff room, office, Principal room, Ncc, Exam, P.E.T & Headmaster
1st Floor -	--- usage---	Class room, store, teacher, Physics Lab, Art room, Activity room & Math lab
2nd floor -	--- usage---	class room, Library, Social Sc, Store, Teacher, Biology Lab, Medical, Computer Lab, Social Sc, Maths Lab, Supw & Computer Lab

CONDITIONS:-

. Fire Prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier (S) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
. The occupier (S) shall train all staff and occupants periodically to make them well conversant in use and operation of fire prevention and safety measures.
. Fire drills/rehearsals should be organized at least once in six months by involving local Fire Station.
. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all tower/blocks of building/premises.

19.1.21

(Ramesh Chandra Sethy)
Deputy Fire Officer
Balasore Circle, Balasore

2021
य/Principal
डहा/K.V. Mahuldiha
ग/Rairangpur

प्राचार्य/Principal
के. वि. महुलडिहा/K.V. Mahuldiha
राईरंगपुर/Rairangpur

Deputy Fire Officer
Balasore Circle, Balasore

Memo No-184/BLS CLE date-19.01.2021

Copy submitted to the Principal, Kendriya Vidyalaya, Mahuldiha, Rairangpur, Dist-Mayurbhanj for information and necessary action.

19.1.21

(Ramesh Chandra Sethy)
Deputy Fire Officer
Balasore Circle, Balasore

Deputy Fire Officer
Balasore Circle, Balasore

Memo No- /BLS CLE date- .01.2021

Copy submitted to the Chief Fire Officer, Fire Prevention Wing, Directorate, Cuttack for information please.

Sd/-
(Ramesh Chandra Sethy)
Deputy Fire Officer
Balasore Circle, Balasore

Memo No- /BLS CLE date- .01.2021

Copy to the A.F.O Rairangpur Fire Station for information and necessary action.

Sd/-
(Ramesh Chandra Sethy)
Deputy Fire Officer
Balasore Circle, Balasore

प्राचार्य/Principal
के. वि. महुलडिहा/K.V. Mahuldiha
राईरंगपुर/Rairangpur