

**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER,
R.W.S&S SUB DIVISION DHARAMGARH**

Letter No. 292

/Dated/ 23/4/24

To

The Principal
Kendriya Vidyalaya
Dharamgarh, Kalahandi

Sub -

Water Testing Report.

Ref: -


Your Letter No: - 142 , Dt :- 22.04.2024

Sir,

With reference to the cited above, the water testing report of water sample submitted by you to this office is enclosed herewith for your information & necessary action.

Encl: As above

Yours faithfully,


23/04/2024
Assistant Executive Engineer
RWS&S Sub-Division
Dharamgarh
Dharamgarh

WATER TESTING REPORT OF RWS&S SUB-DIVISIONAL LABORATORY, DHARAMGARH

Name of the School :- KENDRIYA VIDYALAYA ,DHARAMGARH
Block / NAC:- Dharamgarh

Sl.No	Test Parameters	Units	Results	Acceptable Limit	Permissible Limit
1	pH	pH Unit	7.32	(6.5 to 8.5)	No Relaxation
2	Fluoride mg/L (as F)	mg/l	2.20	1.0	1.5
3	Chloride mg/L (as Cl)	mg/l	80	250	1000
4	Hardness (as CaCo3)	mg/l	212	200	600
5	TDS mg/L	mg/l	887.9	500	2000
6	Conductivity	µmho/cm	1366	—	
7	Total Alkalinity (as CaCo3)	mg/l	220	200	600
8	Calcium (as Ca)	mg/l	30.46	75	200
9	Magnesium (as Mg)	mg/l	33.04	30	100
10	Iron (Fe)	mg/l	0.319	0.30	1.00

K. Singh
23.04.24

Lab. Chemist
RWS&S Sub-Divisional
Water Testing Laboratory
Dharamgarh

[Signature]
23/04/24
Assistant Executive Engineer
RWS&S Sub-Division
Dharamgarh