

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sachin Kumar, DSE

(Name of Officers with designation) from Garrison Engineer PHED

inspected the

(Name & Address of the school) on(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ULR: TC 820725700006572F dt 24.04.25, dated

of (PHED Lab) certified that the

.....(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 Year From

Date of Issue.

Signature with Seal

Name

Designation

Name & Address of the Office / Department :

(Sachin Kumar, DSE)
Garrison Engineer
Air Force Station
Jaipur (Jaipur)

To

PM Shri KVNO.1

Alampur AFS

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Idma Laboratories Limited



TC-8207

TEST REPORT


ULR : TC82072570006572F

Page No. 1/2

Lab No.	240425L-FD-021	Page No. 1/2	
Customer#	Garrison Engineer (AF) Military Engineer Services Adampur Punjab		
Type of Sample#	Borewell Water		
Customer's Description of Sample#	Borewell Water		
Quantity#	5 Ltr.		
Packing, Markings, Seal & Quantity#	Plastic Can, Location-Dauble Story Pump		
Mode of Collection of Sample	Sample Collected By Idma Lab Person		
Work Order No.#	4021/GEN/FRI/E4	Dated	04/04/2025
Date of Receipt of Sample	24/04/2025		
Period of Analysis	24/04/2025 To 30/04/2025		
Visual Observation	N/A		
Date of Reporting	30/04/2025		
Testing Protocol	IS 10500:2012 Amdt 1 to 4		

RESULTS

S.No.	Test Parameter	Units	Results	Requirements		Test Methods
				Acceptable Limit (Max)	Permissible Limit (Max)	
	Chemical Testing (Water)	-	-	-	-	-
1	Color	Hazen	<1	Max. 5	Max. 15	IS 3025 (Part 4) : 2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018
3	pH	-	7.57	6.5-8.5	No Relaxation	IS 3025 (Part 11) : 2022
4	Calcium (as Ca)	mg/L	72.5	Max. 75	Max. 200	IS 3025 (Part 40) : 2024
5	Chloride (as Cl)	mg/L	25.8	Max. 250	Max. 1000	IS 3025 (Part 32) : 1988
6	Total Hardness (as CaCO3)	mg/L	267.8	Max. 200	Max. 600	IS 3025 (Part 21) : 2009
7	Total Dissolved Solids	mg/L	396.0	Max. 500	Max. 2000	IS 3025 (Part 16) : 2023
8	Sulphate (as SO4)	mg/L	10.2	Max. 200	Max. 400	IS 3025 (Part 24/Sec 1) : 2022
9	Turbidity	NTU	<1	Max. 1	Max. 5	IS 3025 (Part 10) : 2023
10	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8) : 2023
	METALS:	-	-	-	-	-
11	Iron (as Fe)	mg/L	0.002	Max. 1.0	No Relaxation	IS 3025 (Part 53) : 2003



Idma Laboratories Limited

Idma Corporate Park,

391, Industrial Area, Phase - 1,

Panchkula - 134113,

Haryana (India)

Tel No. 0172 - 5064827, - 5064830

Website : www.idmagroup.co.in

Email : commercial@idmalab.co.in

Disclaimer :

- The Test Report is only for the sample tested.
- Samples not drawn by us unless otherwise stated.
- Total liability of Idma Laboratories Limited is limited to the invoiced amount.
- If sample(s) not consumed, they will be stored & retained as per Company Policy / quality System Procedure.
- The Test Report shall not be reproduced except in full without the written approval of the laboratory.
- The Test Report is intended only for guidance & not for legal purpose or for advertisement.
- The Test Report in full or parts shall not be used for promotional or publicity purpose.
- Legal disputes are subjected to Panchkula Jurisdiction only.
- Any complaint/discrepancies in this Test Report Should be communicated in writing within 15 days of the dispatch of Test Report.
- In case of any dispute, the terms & conditions of Idma Laboratories Limited shall prevail.
- In case of any feedback/complaints, please send email at testing@idmagroup.co.in or call at 0172 - 5064827 / 5064830



Idma Laboratories Limited



TEST REPORT

ULR : TC820725700006572F

Page No. 2/2

ULR : TC820725700006572F

Page No. 2/2

Lab No.		240425L-FD-021				Test Methods
S.No.	Test Parameter	Units	Results	Requirements		
				Acceptable Limit (Max)	Permissible Limit (Max)	
12	Magnesium (as Mg)	mg/L	21.0	Max. 30	Max. 100	IS 3025 (Part 46) :2023
	Biological Testing (Water)	--	-	--	--	--
13	E. coli	/100ml	Absent	Shall not be detectable in any 100ml sample	--	IS 15185: 2016
14	Total Coliform Bacteria	/100ml	Absent	Shall not be detectable in any 100ml sample	--	IS 15185: 2016


Opinion :

Remarks:- The Test report pertains to the sample, as collected by the IDMA lab person from the customer premises and the result related only to the tested sample. BLQ:- Below limit of quantification, LOQ:- Limit of quantification.


Represents details provided by the customer.

End of Report

Reviewed by



Authorised signatory



Laboratories Limited

Corporate Park,

Industrial Area, Phase - 1,

- 134113,

(a)

5064877 - 5064830

Disclaimer :

- The Test Report is only for the sample tested.
- Samples not drawn by us unless otherwise stated.
- Total liability of Idma Laboratories Limited is limited to the Invoiced amount.
- If sample(s) not consumed, they will be stored & retained as per Company Policy / quality System Procedure.
- The Test Report shall not be reproduced except in full without the written approval of the laboratory.
- The Test Report is intended only for guidance & not for legal purpose or for advertisement.
- The Test Report in full or parts shall not be used for promotional or publicity purpose.
- Legal disputes are subjected to Panchkula Jurisdiction only.

Report to be received within 15 days of the dispatch of Test