

Tele: Mil : 3320
Civil : 2652176


Garrison Engineer
'N' Area, Airport Road
Chandigarh-160003

2000/KV/TS/39/E2 dt 25 Feb 2026

✓ Kendriya Vidyalaya
'K' Area, Zirakpur
Distt-Mohali
PIN-140603

SECURITY AND SAFETY OF THE SCHOOL BUILDING AND BOUNDARY WALL

1. Ref your office letter No. फा.क्र. Misc/के.वि.-जीरकपुर/2025-26/479 dt 07 Feb 2026.
2. It is intimated that visual inspection of school building has been carried out by office of AGE B/R-I. There are no cracks or distress visible on structural components. Hence, building is found to be safe as per visual inspection.
3. However, seepage has been observed at some locations which needs to be addressed through maintenance.
4. This is for your info & necessary action pl.


(Sumit, IDSE)
EE
Garrison Engineer

Copy to:-

AGE B/R-I Chandigarh : For info wrt your letter No. 200/Gen/376/E2 dt 23 Feb 2026.