Dealers in : Fire & Safety Equipments
Authorised Dealers of KANEX & PALEX Brand of Fire Equipments

Ref. No. : CERT_2023_FRTC_NOV_53

Date : 12-Nov-23

FIRE EXTINGUISHER REFILLING & TESTING CERTIFICATETo,
Kendra Vidyalay No - 2 Infantry Lines




New Jail Road, Jamnagar, Gujarat-361005

This is to certify that we have Refilled & Tested the following fire extinguishers.


ITEM NO	MAKE	TYPE	Quantity	SR.NO	CAPACITY	STORED PRESSURE	REFILL DATE	DUE DATE	REMARKS
1	---	ABC	2	11496,11497	02 KG	15 bar	12-Nov-23	11-Nov-24	TESTED OK
2	---	DCP	1	11498	02 KG	45 grams cartridge	12-Nov-23	11-Nov-24	TESTED OK
TOTAL NO OF FIRE EXTINGUISHERS					1				

VALIDITY : 1 Year**EXPIRY DATE** 11-Nov-24**HYDRO-TEST** **RE_PAINTING**

We assure. that the above Fire Extinguishers are in Good Working Condition as per the IS 13849 and IS 15683.

(12 months warranty for pressure drop, if lock seal intact except body or valve manufacturing defect.)

VIJAYA FIRE ENGINEERING WORKS



Dealers in : Fire & Safety Equipments
 Authorised Dealers of KANEX & PALEX Brand of Fire Equipments

Ref. No. : CERT_2023_FRTC_NOV_42

Date : 09-Nov-23

FIRE EXTINGUISHER REFILLING & TESTING CERTIFICATE

To,
Kendra Vidyalay No - 2 Infantry Lines

New Jail Road, Jamnagar, Gujarat-361005

This is to certify that we have Refilled & Tested the following fire extinguishers.

ITEM NO	MAKE	TYPE	Sr.NO	Quantity	CAPACITY	STORED PRESSURE	REFILL DATE	DUE DATE	REMARKS
1	---	ABC	11551-11557	7	05 KG	15 bar	09-Nov-23	08-Nov-24	TESTED OK
2	---	Water Co2	11558-11561	4	09 Ltrs	60 grams cartridge	09-Nov-23	08-Nov-24	TESTED OK
3	---	ABC	11562-11563	2	02 KG	15 bar	09-Nov-23	08-Nov-24	TESTED OK
4	---	DCP	11564-11565	2	02 KG	45 grams cartridge	09-Nov-23	08-Nov-24	TESTED OK
TOTAL NO OF FIRE EXTINGUISHERS				15					

VALIDITY : 1 Year | **EXPIRY DATE** **08-Nov-24**
HYDRO-TEST | **RE_PAINTING**

We assure that the above Fire Extinguishers are in Good Working Condition as per the IS 13849 and IS 15683.



[Handwritten Signature]

