

OFFICE OF THE EXECUTIVE ENGINEER  
PD, PWD, MUZAFFARNAGAR

No. 608/के.वि.मु.नगर/25

Dated 10.02.2025

To

The Principal  
PM SHRI Kendriya Vidyalaya  
Muzaffarnagar, Circular Road,  
Muzaffarnagar

Sub.: Safety Certificate in respect of School Building KV Muzaffarnagar.

Ref.: F.17/के.वि.मु.नगर/2023-24/ Dated 09-01-2025

Sir,

With reference to the letter mentioned above, it is to certify that the school building of PM Shri Kendriya Vidyalaya, Muzaffarnagar, has been inspected by Shri Harvansh Singh, Assistant Engineer on 10.02.2025. This school building is a load bearing structure, if the structure is examined in consideration of new codes of Bureau of India Standards (BIS) and the latest seismological data, it is felt that the building is not totally earthquake resistant.

During the inspection of school building visually, no crack has been found in walls and slabs. Building is safe, in normal conditions, for students and staff.

School Building's structural audit to be reviewed after One year.

*Self attested:*  
*[Signature]*

प्राचार्य/Principal  
पी.एम.श्री. केन्द्रीय विद्यालय  
PM Shri Kendriya Vidyalaya  
मुजफ्फरनगर (उ०प्र०) Muzaffarnagar (U.P.)

Yours faithfully,

*[Signature]*  
(Anil Rana)  
Executive Engineer  
P.D., P.W.D  
Muzaffarnagar