OFFICE OF THE COMMANDANT 118 BN BSF SRIKARANPUR, SRIGANGANAGAR, RAJASTHAN

TO WHOM IT MAY CONCERN

It is certified that the Five (05) Building structures (Load bearing) of this HQ where KV School hasbeen functioning since July 2025 were constructed in the year 1991. These structures have completed life of 35 years approximately. As per CPWD manual 2019 (SOP No.3/5) chapter no.03 Page no.07. The prescribed economic life of load bearing structure under normal occupancy and maintenance conditions is considered as 55 years which depends upon several factors such as location, utilization, specification, maintenance and up keeping/caretaking. As per appearance, the condition of these buildings under present normal conditions is **Satisfactory** and can be utilized in general conditions except natural disaster like Earthquake, heavy rain etc. The certificate is issued subject to condition that the user shall take necessary safety measures as required under various acts/rules from time to time.

For Fire Safety, There are 02 (Two) Nos fire safety extinguishers installed in KV school premises and 04 (Fifty) Nos fire safety equipments are installed within the radius of 50 (Fifty) mtrs of premises.

For Commandant 19/8/25

118 BN BSF