

CERTIFICATE NO: 1962

TEST CERTIFICATE

DATE: 26/06/2024

Date:....

This is to certify that under noted Portable/Trolley mounted type Fire Extinguishers Refilling and servicing job done by us as per technical data mentioned.

Sl. No.	Type of Fire Extinguisher	No of Extinguisher Tested & Refilled	No. of Extinguisher Rejected	Test Pressure (25 – 30 Kg. Cm.²)	Cartridge Under Fitted (220 Grams)
01	ABC type fire extinguisher capacity 4 KG	5 NOS	NIL	Checked ok	STOREDPRESSURE TYPE
02	DCP type fire extinguisher capacity 5 KG	6 NOS	NIL	Checked ok	CARTRIDGE TYPE
03	CO2 type fire extinguisher capacity 4.5 KG	1 NOS	NIL	Checked ok	STOREDPRESSURE TYPE
Nam	e: KENDRIYA VIDYA	LAYA	Total Nos of Extinguishers: 12		
Address : GOLAGHAT,ASSAM				Date of Refill : 26.06.2024 Date of Expiry : 25.06.2025	
Рhope No: 9706042299					

After the completion of the required job, the fire Extinguishers are delivered at their premises/ factory.

NOTE: *ABC & DCP EXTINGUISHERS SHOULD NOT BE OLDER THAN 10 YEAR.

*CO2 EXTINGUISHERS SHOULD NOT BE OLDER THAN 15 years.

*HYDROTEST OF 30KG/UM2 OF2.5 MINS OF ULTRASONIC THICKNESS TESTING SHOULD BE DONE FOR CO2 EXTINGUISHERS AFTER EVERY FIVE YEAR &

SAME APPLIES FOR ABC EXTINGUISHERS.

Authorized signatory

For, Fire Safety Devices

Office Address : Bengenakhowa, G.F. Road, R.K. Baruah Path, Golaghat - 785621 (Assam)

Mob : +91 88762 38543, +91 93651 21851, GSTIN : 18AERPI7900Q2ZO, Email : suhailirfan07@gmail.com

OUR SERVICES : FIRE EXTINGUISHER, FIRE HYDRANT SYSTEM, SPRINKLER, FIRE DETECTOR, FIRE ALARM, EXTINGUISHER REFILLING ETC.