Government of Bihar

Publice Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Sample Collected by :-KENDRIYA VIDYALAYA,MAHARAJGANJ,SIWAN 841233

Sample Receiving Date:02.12.2025

SL. No.	04.12.2025	Block	Panchyat	Ward	Name of Location	Parameters														
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO_3	SO_4	F	As	Total
1		Maharajganj	Nagar Panchyat		Kendriya Vidyalaya,Maharajganj	6.52	0.2		46	21.56	7.84	4.7	12.81	20.2	0.16	BDL	BDL	BDL	NIL	<1.1
Acceptable Limits						6.5	5.0	62.0	500	200	75	30	250	200	1.0	45	200	1.0	0.01	
Permissible Limits						8.5	NR	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	

All parameters are under disrable limits

04/12/25

Chemist P.H.Division Siwan