GSTIN : 06BYDPB2673Q1Z5



INDIAN FIRE & SAFETY WORKS



Dabwali Road, Behind Fire Brigade, SIRSA

Contact No. 94162-85101, 97283-82985

Deals in : ISI 9001:2015 Marked fire extinguishers, Hydrant System, Pollution Mask & Protective Equipment

Traning & Placement Fireman Diploma

Dealsin : All Types of Fire Fighting Equipments

REFILL DATE:- 10/09/2025

M/S. PM SHRI KENDRIYA VIDYALAYA No.2
SIRSA HARYANA

REFILL DUE DATE:- 09/09/2026

TEST CERTIFICATE

TO WHOME IT MAY CONCERN

This is Certify that all the fire Extiguishers which are refilled. Solid by us are hydraulically tested at pressure 25kg/cm for a minute and the material used map power in refilling of all the Fire Extinguishers are as per ISI Mark, we are using Leak Test (A stringent 24 hours leak test detects minute traces of escaping gas), using Helium Testing (The Helium test deceits tiny amounts of nitrogen leakage in a vacim chamber) & using Discharge Test (This Test detect any corrosiion or areas of weakness in the extinguisher's body). All the fire Extinguishers are duly painted/Washed. Hence all the Fire Extinguisher are in Working Condition.

Total No. of Fire Extinguisher :-

D.C.P Fire Extinguisher	Kg.....	S. No.....	Pic
CO2 Fire Extinguisher New	Kg.....	S. No.....	Pic
CO2 Fire Extinguisher Refill	Kg..4.5kg.....	S. No.....01.....	Pic
AFFF Foam Fire Extinguisher New	Kg.....	S. No.....	Pic
AFFF Foam Fire Extinguisher Refill	Kg.....	S. No.....	Pic
ABC Fire Extinguisher New 4 Kg.	Kg.....	S. No.....	Pic
ABC Fire Extinguisher Refill 4 Kg.	Kg.....	S. No.....	Pic
ABC Fire Extinguisher New 6 Kg.	Kg.....	S. No.....	Pic
ABC Fire Extinguisher Refill 6 Kg.	Kg....6kg.....	S. No.....12.....	Pic
ABC Fire Extinguisher New 9 Kg.	Kg.....	S. No.....	Pic
ABC Fire Extinguisher Refill 9 Kg.	Kg.....	S. No.....	Pic
Water CO2 Fire Extinguisher New	Kg.....	S. No.....	Pic
Water CO2 Fire Extinguisher Refill	Kg.....	S. No.....	Pic

INDIAN FIRE & SAFETY WORKS PROP.

For Indian Fire & Safety Works

Total Nos.....13.....