PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,PANCHKULA

PHED Haryana

Website :- https://phedharyana.gov.in/

Memo No:-

Date:-

Subject : Bacteriological Examination Report of Water Sample

Sample ID	PKL/05622/12/2025	**Sample Details**	**Date & Time**
Sample Classification	Private	Collected By	.
Sender	Monika Kaushik	Collection Date	12/12/2025 at 15:53
Location :-	, PM SHRI KV ITBP BTC BHANU,PANCHKULA	Received at lab	12/12/2025 at 15:54
Latitute :- 76.918128	Longitude :- 30.633032	Tested at Lab	15/12/2025

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- The Results Given above are related to the sample as received and tested in PANCHKULA lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.

Water Sample has been found **"CONFORMING "** to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found **"POTABLE"**

SONIA,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORYPANCHKULA
email:-chemist.panchkula@phedharyana.gov.in

.....End of Report.....

मोनिका कौशिक,
प्राचार्या,
पीएम श्री के.वि. आई.टी.बी.टी. भानु,
पंचकुला -134103

अध्यक्ष,
विद्यालय प्रबंधन समिति,
पीएम श्री के.वि. आई.टी.बी.टी. भानु